

डाक प्रमाणित UNDER CERTIFICATE OF POSTING

संस्थापक : 26591762, 26591754,
26597218, 26591767, 26591450
तार : टेक्नालाजी दिल्ली
फैक्स : 011-26581992, 26582037, 26582277

TEL : 26591762, 26591754,
26597218, 26591767, 26591450
GRAMS : TECHNOLOGY DELHI
FAX : 011-26581992, 26582037, 26582277

भारतीय प्रौद्योगिकी संस्थान, दिल्ली



INDIAN INSTITUTE OF TECHNOLOGY, DELHI



हौजखास, नई दिल्ली -110016, HAUZKHAS, NEW DELHI-110016

निर्माण विभाग WORKS DEPARTMENT

दर आमंत्रण सूचना

NOTICE INVITING QUOTATION

द.आ.सू.सं : भा.प्रौ.सं.दि./सं अ./NIQ NO : IITD/IE/ 783	द.आ.सू. तारीख NIQ DATE 22/03/2013	दर सूची खोलने की तारीख OPENING DATE OF NIQ 04/04/2013
IITD/EE(E)/2012-13		

कार्यपालक अभियन्ता (.....) संस्थान में निम्नलिखित सामग्री की आपूर्ति हेतु प्रामाणिक फर्मों/व्यापारियों से मोहरबन्द दर सूची आमन्त्रित करते हैं
Executive Engineer (.....) Invites sealed quotations from the genuine firms / dealers for the material given below required at this Institute :-

विषय / Sub.....

PROCUREMENT OF 1.0 TR WINDOW TYPE AC FIVE STAR RATING

क्रम सं. Sl. No.	वस्तु का नाम तथा पूर्ण विवरण Name of article & full specification	इकाई Unit	मात्रा Quantity
1	1.0 TR WINDOW TYPE AIRCONDITIONERS ^{four star} FIVE STAR RATING (Specifications as enclosed with N/A ANNEXURE I & II. Supply of 1.0 TR window Type Air-Conditioners Five Star Rating Make :-Voltas/Blue Star/Hitachi/LG/ TERMS AND CONDITIONS. Rates are inclusive of all taxes and duties.2.F.O.R IIT Delhi.3.Payment after delievery 4. Earnest money in the shape of P.O/B.C/ D.O in favour of Registrar IIT Delhi for Rs 43300/- only 5. Quotation shall be submitted duly completed in two separate Envelopes. one Part I Technical and commercial bid and Part II Financial bid. Both the bids shall be submitted together on or before the due date and time. The name of firms, date of opening bids, Technical bids and financial bid shall clearly be super scribed on the respective Envelope. 6. The price bid of only those bidder shall be opened whose technical bids are in line with specifications of the technical bid of quotations. 7. Date of submission of bids 04/04/2013 up to 3.00 PM 8. Date of opening Technical bid 04/04/13 at 330 PM	no	100.000
			43300.00

टिप्पणी : निबंधन एवं शर्तें दूसरी तरफ दी गई है।
NOTE : THE TERMS & CONDITIONS OVERLEAF

बयाना राशि :
Earnest Money : 43,300/-

दर सूची खोलने की तिथि/तारीख को अपराहन 2.30 बजे तक दर सूचियां प्राप्त की जाएंगी तथा उसी दिन अपराहन 3.00 बजे दर सूचियां खोली जाएंगी। दर सूची प्राप्त करने की तिथि/तारीख को अपराहन 2.30 बजे के पश्चात प्राप्त दर सूचियों को अस्वीकृत किया जा सकता है।

The quotations will be received upto 2.30 p.m. and opened at 3.00 p.m. on due date of opening. Quotations received after 2.30 p.m. on due date are liable to be rejected.

सेवा में, हमारे पास सत्रीबद्ध सभी फर्म
सहायक कार्यपाल अभियन्ता [] सहायक कुलसचिव (लेखा)/उप कुलसचिव (लेखा)
कार्यपाल अभियन्ता (.....) तथा संस्थान अभियन्ता

अधीक्षक, निर्माण Superintendent Works
भारतीय प्रौद्योगिक संस्थान
INDIAN INSTITUTE OF TECHNOLOGY

Part-1 Technical Cum Commercial Bid
Annexure -1
INDIAN INSTITUTE OF TECHNOLOGY DELHI:
HAUZ KHAS. NEW DELHI –110016
(AIR-CONDITIONING SUB DIVISION)

Corrigendum

Name of work:- Replacement of 15 years and more old inefficient Air-Conditioners and procurement of 1.0 Tr. WTAC for faculty and group A officers at IIT Delhi.

Sub Head :- Procurement of 1.0 Tr. WTAC for faculty and group A officers at IIT Delhi.

Ch .to :- PLN-05/EW

Design Parameters

Window type Air –Conditioner

Sr. No.	Description of Item			
	Given as	Read as		
1.	Supplying of 1.0 TR Window type Air –Conditioner		Fill the technical Specifications as per Annexure –I	Condition as per Annexure –II
	Rated cooling capacity nominal (Watt) : 3500	: 3500		
	Noise Level (indoor)(Db) Max : ≤50	: ≤50		
	Minimum Star Rating : 5 Star	: 4 Star		
	EER(W/W) : ≥3.20	: ≥3.20		
	Make of rotary compressor :- Hitachi/Carrier/Emerson//Tecumseh	Hitachi/Carrier/Emerson//Tecumseh		
	Sheet thickness for base(Outdoor Unit) : >1.20mm	: >1.20mm		
	Sheet thickness for Body(Outdoor Unit) : >0.70mm	: >0.70mm		
	Refrigerant : R-22or R-410	R-22or R-410		
<p>Note:- 1. Quoted Rates separately for Refrigerant R22 or other ECO friendly refrigerant. 2. Annexure –I and Annexure –II are part of the Quotation 3. Technical details are mandatory to be filled by the bidder in Annexure –I and Annexure –II</p>				
List of approve Makes				
	Name of Material	Manufacturer/ Brand Name		
	Window type Air –Conditioner	Carrier /Blue Star/LG/ Samsung/ Hitachi/Tecumseh/O-General/WhirlPool /Godrej/ Daikin/Voltas /York /Onida/GE/Mitsubishi Electric/Toshiba/Panasonic		

Part-II Financial Bid

INDIAN INSTITUTE OF TECHNOLOGY DELHI:
HAUZ KHAS. NEW DELHI -110016
(AIR-CONDIONING SUB DIVISION)

Corrigendum

Name of work:- Replacement of 15 years and more old inefficient Air-Conditioners and procurement of 1.0 Tr. WTAC for faculty and group A officers at IIT Delhi.

Sub Head :- Procurement of 1.0 Tr. WTAC for faculty and group A officers at IIT Delhi.

Ch .to :- PLN-05/EW

Window type Air -Conditioner

Schedule of quantity

Sr. No.	Description of Item	Read as	Rate Per Unit	Amount
	Given as			
1.	Supplying of 1.0 TR Window type Air - Conditioner Rated cooling capacity nominal (Watt) : 3500 Noise Level (indoor)(Db) Max : ≤50 Minimum Star Rating : 5 Star EER(W/W) : ≥3.20 Make of rotary compressor :- Hitachi/Carrier/Emerson//Tecumseh Sheet thickness for base(Outdoor Unit) : >1.20mm Sheet thickness for Body(Outdoor Unit) : >0.70mm Refrigerant : R-22or R-410	: 3500 : ≤50 : 4 Star : ≥3.20 Hitachi/Carrier/Emerson//Tecumseh : >1.20mm : >0.70mm : R-22or R-410	100 Nos.	In Figure In Words
Total Rs.				
Discount if any In Figure In Words				
G. Total Rs.				

EE(E)  AE(E)/AC 