INDIAN INSTITUTE OF TECHNOLOGY: DELHI HAUZ KHAS, NEW DELHI-110016. (WORKS SECTION)

CORRIGENDUM

Name of Work: Replacement of Conventional light to LED light fixtures at Taxila Appt. Housing in IIT Delhi.

<u>Tender ID</u>: IITD/WORKS (SP-4062)2022][2022_IIT_732277_1]

Following modifications in makes have been carried out & the dates of Tender are extended as under.

GIVEN AS			
Item. No	Name of Item	Approved Make.	
4	Supplying and installation of Surface mounting LED batten for T8 LED retro fit Lamp with 20 Watt LED tube light single side connection complete fixture with following features: - Suitable for operating voltage and frequency: 130-300 Va.c, 50 Hz.; wattage 20 Watts; Length 1200mm (+/-6%); Output lumens not less than 2000 lm; CCT 6500K; Nominal surge protection 2.5 kV;Power factor not less than 0.9, IP 54. Length 4 feet. N.B.: Bidder shall have to submit type test certificate of BIS for the product (model) they intended to supply, latest valid Certificate of OEM for ISO 9001, 14001 & 45001. Warranty: 5 years.	[Make:- Philips/ Panasonic/ Bajaj/ Havells]	
5	Supplying and installation of Surface mounting Mirror light having two B22 base holder for LED lamp fixture with following features:- Suitable for operating voltage and frequency: 130-300 Va.c, 50 Hz.; wattage 20 Watts; Length 450mm(+/-6%); Nominal surge protection 2.5 kV; IP 54.	[Make:- Philips/ Panasonic/ Bajaj/ Havells]	
7	Supplying and installation of Recess/Surface mounting round LED luminaire with surface accessories module for fixing equipped with diecast aluminium / CRCA housing, anti glare polycarbonate diffuser with energy efficient electronic driver with following features:-Suitable for operating voltage and frequency: 130-300 Va.c, 50 Hz.; wattage not more than 12 Watts;Output lumens not less than 650 lm; CCT 6000K; Nominal surge protection 2.5 kV;Power factor not less than 0.9; Minimum IP protection 54; N.B.: Bidder shall have to submit type test certificate of BIS for the product (model) they intended to supply, latest valid Certificate of OEM for ISO 9001, 14001 & 45001. Warranty: 5 years.	[Make:- Philips/ Panasonic/ Bajaj/ Havells]	
READ AS			
4	Supplying and installation of Surface mounting LED batten for T8 LED retro fit Lamp with 20 Watt LED tube light single side connection complete fixture with following features: - Suitable for operating voltage and frequency: 130-300 Va.c, 50 Hz.; wattage 20 Watts; Length 1200mm (+/-6%); Output lumens not less than 2000 lm; CCT 6500K; Nominal surge protection 2.5 kV;Power factor not less than 0.9, IP 20(Indoor type). Length 4 feet. N.B.: Bidder shall have to submit type test certificate of BIS for the product (model) they intended to supply, latest valid Certificate of OEM for ISO 9001, 14001 & 45001. Warranty: 5 years.	[Make:- Philips/ Panasonic/ Bajaj/ Havells]	
5	Supplying and installation of Surface mounting Mirror light having two B22	[Make:-	



	base holder for LED lamp fixture with following features: - Suitable for operating voltage and frequency: 130-300 Va.c, 50 Hz.; wattage 20 Watts; Length 450mm(+/-6%); Nominal surge protection 2.5 kV; IP 20(Indoor type). Warranty: 5 Years.	Philips/ Panasonic/ Bajaj/ Havells]
7	Supplying and installation of Recess/Surface mounting round LED luminaire with surface accessories module for fixing equipped with diecast aluminium / CRCA housing, anti glare polycarbonate diffuser with energy efficient electronic driver with following features:-Suitable for operating voltage and frequency: 130-300 Va.c, 50 Hz.; wattage not more than 12 Watts;Output lumens not less than 650 lm; CCT 6000K; Nominal surge protection 2.5 kV;Power factor not less than 0.9; Minimum IP 20(Indoor type); N.B.: Bidder shall have to submit type test certificate of BIS for the product (model) they intended to supply, latest valid Certificate of OEM for ISO 9001, 14001 & 45001. Warranty: 5 years.	[Make:- Philips/ Panasonic/ Bajaj/ Havells]

Last Date and Time for Uploading of Bids : 05-01-2023 (15:00 Hrs) Date and Time of Opening of Technical Bids: 06-01-2023 (15:00 Hrs)

All the other terms & Conditions will remain un-changed.

Approval may kindly accorded please.

JE(E)