
IIT Delhi



C ... Nil I Nil O Nil

T.S./JE Plg

Page 1 of 51

Name of work: - SITC of Split & WAC Units at different places in IIT Delhi (ACCR 03 May 2024)

NIT for the above-mentioned work has been prepared with the following:

1	Amount of NIT (INR)	:	43,60,259.00
2	Earnest money (INR)	•	87,205.00
3	Completion time	•	50 days
4	Last date of submission	••	27-06-2024 upto 3 PM
	(online)		
5	Date of opening	:	28-06-2024 after 3 PM
6	Form of NIT	•	PWD / IITD – 8
7	Schedule applicable	•	Market Rate, DSR (E&M)
8	Material stipulated	•	As per Schedule of Work
9	Chargeable heads		35.01.01
10	Work code no.	•	2021/006/0616
11	NIT No.	•	616/30/IITD/AC/2024-25

Certified that this NIT contains 1 to 51 pages. NIT amounting to Rs.43,60,259.00 is approved.

T.S. Plg.

Assistant Executive Engineer in-charge AC Division

C ... Nil I Nil O Nil

AEE-in-charge AC Division

Page 2 of 51

CONTENTS

Sr.	Description	Page		
No.		From	То	
1	Notice Inviting Tender	04	05	
2	Schedule of NIT	06	07	
3	Instruction for online bid submission	07	10	
4	Information & instruction to bidders	11	14	
5	List of Mandatory Documents to be uploaded	15	16	
6	IITD / CPWD 6 Form	17	20	
7	Integrity Pact	21	27	
8	IITD – 7/8 Form	28	29	
9	Proforma of Schedule	30	35	
10	Commercial & Additional conditions	36	41	
11	Declaration (Annexure – 1)	42	42	
12	Annexure – 2	43	43	
13	Bid Submission Check List	44	44	
14	Schedule of Quantity	45	51	

C ... Nil I Nil O Nil

T.S./JE Plg

IIT Delhi

INDIAN INSTITUTE OF TECHNOLOGY DELHI

AC DIVISION

NOTICE INVITING E-TENDER

IITD/WORKS (SP- 4673)/2024

Assistant Executive Engineer-in-charge, AC Division, Indian Institute of Technology Delhi, Hauz Khas, New Delhi – 110016, Ph. No. 011-2659 1746 on behalf of Board of Governors invites online Item Rate Tender from firms / contractors of repute in two bid system as per details given below.

1	Name of work	:	SITC of Split & WAC Units at different places in IIT Delhi (ACCR 03 May 2024)
2	NIT No.	:	616/30/IITD/A <mark>C/20</mark> 24-25
3	Estimated Cost (Rs.)	:	43,60,259.00
4	Earnest Money Deposit (Rs.)	:	87,205.00 (No exemption allowed)
5	Period of completion	:	50 days
6	Last date & time of bid submission	:	Upto 3 PM of 27-06-2024
7	Performance Bank Guarantee	:	5 percent of the tendered amount

The bid forms and other details may be downloaded from Central Public Procurement Portal (<u>http://eprocure.gov.in/eprocure/app</u>). Aspiring bidders who have not enrolled / registered in e-procurement should enrol / register themselves before participating through web site <u>http://eprocure.gov.in/eprocure/app</u>. The portal enrolment is free of cost. Bidders are advised to go through instructions provided at "Instructions for online bid submission."

Bidders can access quotation / tender documents on the website (for searching in the NIC site), kindly go to quotation search option and type 'IIT'. Thereafter, click on "GO" button to view all IIT quotations. Select the appropriate quotation / tender and fill them with all relevant information and submit the completed Quotation / Tender document online on the website <u>http://eprocure.gov.in/eprocure/app</u> as per the schedule given in the next page.

No manual bids will be accepted. All bids (both Technical & Financial) should be submitted in the e-procurement portal.

Assistant Executive Engineer-in-charge, AC Division For & on behalf of BOG, IIT Delhi

Ch. Head : 35.01.01	PLN	Work Code : 2021/006/0616
C Nil I Nil O Nil		Page 4 of 51

T.S./JE Plg

IIT Delhi

Copy to:-

- 1. D.A. (Works Accounts)
- 2. A.R. (A/C)
- 3. A.R. (Store Purchase Section)
- 4. Notice Board
- 5. Website Administrator, IIT Delhi
- 6. Office copy

HOFELHIACDINISION

SCHEDULE

C ... Nil I Nil O Nil

T.S./JE Plg

Page 5 of 51

1	Name of organisation	•	Indian Institute of Technology Delhi
2	Tender / Quotation type (open / limited / EOI / auction / single)	:	Open
3	Tender / Quotation category (services / goods / works)	:	Goods & Works
4	Type of Contract (work / supply / auction / service / buy / empanelment / sell)	:	Work & Supply
5	Form of contract (IITD – 7/8)	:	IITD – 8
6	Work Category (civil / electrical / fleet management / computer systems)	:	Electrical
7	Is multi-currency allowed?	:	No
8	Date of publishing / issue / start	:	20/06/2024 (15.00 PM)
9	Document download start date	:	20/06/2024 (15.00 PM)
10	Document download end date	:	27/06/2024 (15.00 PM)
11	Date & time of pre-bid meeting	:	No pre-bid meeting be held
12	Venue of pre-bid meeting	:	Not applicable
13	Last date & time of uploading of bids	:	Upto 3 PM of 27-06-2024
14	Date & time of opening of Technical Bids	Ċ	28-06-2024 after 3 PM
15	Tender fee	$\mathbf{\dot{\cdot}}$	Free of cost
16	Earnest Money Deposit (EMD) Rs.	:	87,205.00 (No exemption allowed)
17	Mode of payment of EMD	:	Can be paid through RTGS/NEFT. IIT Delhi Bank details are as under: Name of the Bank A/C : IITD Revenue Account SBI A/C No. : 10773572622 Name of the Bank : State Bank of India, IIT Delhi, Hauz Khas, New Delhi-110016 IFSC Code : SBIN0001077 MICR Code : 110002156 Swift No. : SBININBB547 (This is mandatory that UTR Number is provided in the on-line quotation/bid. (Kindly refer to the UTR Column of the Declaration Sheet at Annexure-II) OR Demand Draft / FDR favouring Registrar, IIT Delhi Payable at SBI, IIT Delhi Branch. Scanned copy of DD / FDR needs to be uploaded alongwith the Technical Bid. Exact Original DD/ FDR shall have to be submitted to the tender

Page 6 of 51

			inviting authority by the bidder as and when required after opening of bid.
17	Bid without EMD / Non-submission of original DD	:	To be considered as UNRESPONSIVE and bid shall summarily be rejected
18	No. of bids / covers (1 / 2 / 3 / 4)	:	2
19	Address for communication	:	Assistant Executive Engineer-in-charge, AC Division, Works Department, IIT Delhi, Hauz Khas, New Delhi – 110016
20	Contact No.	:	011 2659 1746
21	e-mail address for communication	:	a <u>26984@admin.iitd.ac.in;</u> pradipk@admin.iitd.ac.in

INSTRUCTIONS FOR ONLINE BID SUBMISSION

As per the directives of Department of Expenditure, this quotation / tender document has been published on the Central Public Procurement Portal (URL: http://eprocure.gov.in/eprocure/app). The bidders are required to submit softcopies of their bids electronically on the CPP portal, using valid Digital Signature Certificates (DSC). The instructions given below are meant to assist the bidders in registering on the CPP portal, prepare their bids in accordance with the requirements and submitting their bids online on the CPP portal.

More information useful for submitting online bids on the CPP portal may be obtained at <u>http://eprocure.gov.in/eprocure/app</u>

REGISTRATION

- 1. Bidders are required to enrol on the e-procurement module of the Central Public Procurement portal (URL: <u>http://eprocure.gov.in/eprocure/app</u>) by clicking on the link, "click here to enrol". Enrolment on the CPP portal is free of charge.
- 2. As part of the enrolment process, the bidders will be required to choose a unique user name and assign a password for their accounts.
- 3. Bidders are advised to register their valid e-mail address and mobile number as part of the registration process. These would be used for any communication from the CPP Portal.
- 4. Upon enrolment, the bidders will be required to register their valid Digital Signature Certificate (class 2 or class 3 certificates with signing key usage) issued by any

C ... Nil I Nil O Nil

certifying authority recognised by CCA India (e.g. Sify / TCS / nCode / eMudhra etc.) with their profile.

- 5. Only one valid DSC should be registered by a bidder. Please note that bidders are responsible to ensure that they do not lend their DSCs to others which may lead to misuse.
- 6. Bidder then logs into the site through the secured log-in by entering their user ID / password and the password of the DSC / eToken.

SEARCHING FOR TENDER DOCUMENTS

- 1. There are various search options built in the CPP portal to facilitate bidders to search active tenders by several parameters. These parameters could include tender ID, organisation name, location, date, value, etc. There is also an option of advanced search for tenders, wherein the bidders may combine a number of search parameters such as organisation name, form of contract, location, date, other keywords etc. to search for a tender published on the CPP portal.
- 2. Once the bidders have selected the tenders they are interested in, they may download the required documents / tender schedules. The tenders can be moved to the respective "My Tenders" folder. This would enable the CPP portal to intimate the bidders through SMS / e-mail in case there is any corrigendum issued to the tender document.
- 3. The bidder should make a note of the unique Tender ID assigned to each other, in case they want to obtain any clarification / help from the Helpdesk.

PREPARATION OF BIDS

- 1. Bidder should take into account any corrigendum published on the tender document before submitting their bids.
- 2. Please go through the tender advertisement and the tender document carefully to understand the documents required to be submitted as part of the bids. Please note the number of covers in which the bid documents have to be submitted. Any deviations from these may lead to rejection of the bids.
- 3. Bidder, in advance, should get ready the bid documents to be submitted as indicated in the tender document / schedule and generally, they can be in PDF / XLS / RAR / DWF formats. Bid documents may be scanned with 100 dpi with black & white option.
- 4. To avoid the time and effort required in uploading the same set of standard documents which are required to be submitted as a part of every bid, a provision of uploading such standard documents (e.g. PAN card copy, annual reports, auditor's certificates, etc.) has been provided to the bidders. Bidders can use "My Space" area available to them to upload such documents. These documents may be directly submitted from the "My Space" area while submitting a bid, and need not be uploaded again and again. This will lead to a reduction in the time required for bid submission process.

SUBMISSION OF BIDS

Page 8 of 51

C ... Nil I Nil O Nil

- 1. Bidder should log into the site well in advance for bid submission so that he / she upload the bid in time i.e. on or before the bid submission time. Bidder will be responsible for any delay due to other issues.
- 2. The bidder has to digitally sign and upload the required bid documents one by one as indicated in the tender document.
- 3. Bidder has to select the payment option as "on-line" to pay the tender fee / EMD as applicable and enter details of the instrument. Whenever, EMD / Tender fees is sought, bidders need to pay the tender fee and EMD separately on-line through RTGS (Refer to Schedule, Page no. 3)
- 4. A standard BOQ Format has been provided with the tender document to be filled by all the bidders. Bidders are requested to note that they should necessarily submit their financial bids in the format provided and no other format is acceptable. Bidders are required to download the BOQ file, open it and complete the white coloured [unprotected] cells with their respective financial quotes and other details (such as name of the bidder). No other cells should be changed. Once the details have been completed, the bidder should save it online, without changing the filename. If the BOQ file is found to be modified by the bidder, the bid will be rejected.

OR

In some cases financial bids can be submitted in PDF format as well (in lieu of BOQ).

- 5. The server time (which is displayed on the bidders' dashboard) will be considered as the standard time for referencing the deadlines for submission of the bids by the bidders, opening of bids etc. The bidders should follow this time during bid submission.
- 6. All the documents being submitted by the bidders would be encrypted using PKI encryption techniques to ensure the secrecy of the data. The data entered cannot be viewed by unauthorised persons until the time of bid opening. The confidentiality of the bids is maintained using the secured Socket Layer 128 bit encryption technology. Data storage encryption of sensitive fields is done.
- 7. The uploaded tender documents become readable only after the tender opening by the authorised bid openers.
- 8. Upon the successful and timely submission of bids, the portal will give a successful bid submission message & a bid summary will be displayed with the bid no. and the date & time of submission of the bid with all other relevant details.
- 9. Kindly add scanned PDF of all relevant documents in a single PDF file of compliance sheet.

ASSISTANCE TO BIDDERS

1. Any queries relating to tender document and the terms and conditions contained therein should be addressed to the tender inviting authority for a tender or the relevant contact person indicated in the tender.

C ... Nil I Nil O Nil

Page 9 of 51

2. Any queries relating to the process of online bid submission or queries relating to CPP portal in general may be directed to the 24 x 7 CPP Portal Help Desk. The contact number of the helpdesk is 18002337315.

GENERAL INSTRUCTIONS TO THE BIDDERS

- 1. The tenders will be received online through portal <u>https://eprocure.gov.in/eprocure/app</u>. In the technical bids, the bidders are required to upload all the documents in PDF format.
- 2. Possession of a valid class II / III Digital Signature Certificate (DSC) in the form of smart card / e-token in the company's name is a prerequisite for registration and participating in the bid submission activities through https://eprocure.gov.in/eprocure/app. Digital Signature Certificates can be obtained from the authorised certifying agencies, details of which are available in the website <u>https://eprocure.gov.in/eprocure/app</u> under the link "Information about DSC".
- 3. Tenderers are advised to follow the instructions provided in the "Instructions to the tenderer" for the e-submission of the bids online through the Central Public Procurement Portal for e-procurement at https://eprocure.gov.in/eprocure/app.

IIT Delhi

AC Division

INFORMATION & INSTRUCTION TO BIDDERS FOR E-TENDERING

Assistant Executive Engineer-in-charge, AC Division, Indian Institute of Technology Delhi, Hauz Khas, New Delhi – 110016, Ph. No. 011-2659 1746 on behalf of Board of Governors invites online **Item Rate Tender** from firms / contractors of repute in two bid system as per details given below:

Sr. No.	NIT No.	Name of Work & Location	Estimated cost put to bid (Rs.)	Earnest money (Rs.)	Period of completion	Last date & time of submission of bid	Time & date of opening of Technical Bid	Time & date of opening of Financial Bid
(1)	616/30/IITD/AC/2024-25	(3) SITC of Split & WAC Units at different places in IIT Delhi (ACCR 03 May 2024)	43,60,259.00	87,205.00 (No exemption ය allowed)	6) 20 days	Upto 3 PM of 27-06-2024	28-06-2024 after 3 PM (0	To be decided after assessing Technical Bids

- 1. The successful bidder shall be required to submit a performance guarantee of 5% of the tendered amount in the form of Bank Guarantee or F.D.R. from a Nationalized / Scheduled Bank within fifteen days of issue of letter of intent before award of work. In case of failure by the Contractor to submit the performance guarantee within the specified period, full earnest money will be forfeited by the Institute and the tender shall be treated as null and void. EMD shall be refunded after submission of PBG. The performance guarantee shall be initially valid up to the stipulated date of completion (i.e. 35 days) plus sixty days beyond that.
- 2. Earnest money (EMD) shall have to be deposited / submitted as stipulated in the schedule. Declaration to be submitted by the bidder as indicated in the list of mandatory documents, if scanned copy of DD / FDR is submitted for EMD.
- **3.** Contractors who fulfil the following requirements shall be eligible to apply. Joint ventures are not accepted.
 - a. Should have satisfactorily completed the works as mentioned below during the last Seven years ending **last day of the month previous to one in which tenders are invited**.

C ... Nil I Nil O Nil

Page 11 of 51

T.S./JE Plg

- i. Three similar works each costing not less than Rs.17,44,000.00, or two similar works each costing not less than Rs.26,16,000.00, or one similar work costing not less than Rs.34,88,000.00.
- 4. The value of executed work shall be brought to current costing level by enhancing the actual value of work at simple rate of 7% per annum; calculated from the date of completion to previous day of last day of submission of bids.
- 5. Similar work means Supply, Installation, Testing & Commissioning of Air Conditioning Units in buildings.
- 6. Work means work done with some Central Government Department / State Government Department / Central Autonomous Body / State Autonomous Body / Central Public Sector Undertaking / State Public Sector Undertaking / City Development Authority / Municipal Corporation of City formed under any Act by Central / State Government and published in Central / State Gazette / any Public Authority.
- 7. Completion certificates are required to be got issued by an officer not below the rank of Executive Engineer of similar works completed by the Firm. The work experience certificates submitted by the bidders shall clearly indicate that:
 - a. The similar work executed shall be as per '5' above
 - b. The completed cost of the work
 - c. Actual date of completion of the work
- 8. IITD is committed to follow the principle of transparency, equity, and competitiveness in public procurement. Before submission of bid, each bidder should sign integrity pact at respective places and submit the bid. If duly signed integrity pact is not submitted by bidder, such bid shall not be considered.
- 9. The intending bidder must read the terms and conditions [both commercial & Additional] & IITD
 6 carefully which will be the part of the Contract. He should only submit his bid if he considers himself eligible and he is in possession of all the documents required.
- **10.** Information and Instructions for bidders posted on website shall form part of bid document.
- **11.** The bid document consisting of plans, specifications, the schedule of quantities of various types of items to be executed and the set of terms and conditions of the contract to be complied with and other necessary documents can be seen and downloaded from website e-procure.gov.in free of cost.
- **12.** But the bid can only be submitted after submission/uploading of EMD as prescribed in the schedule.
- **13.** Copy of all mandatory documents as desired in the NIT shall be scanned and up-loaded to the e-Tendering website within the period of bid submission. During scrutiny of technical bids, if required, bidders may be asked to submit original documents for cross checking. However, certified / original copy of all the scanned and up-loaded documents shall have to be submitted by the lowest bidder only within a week physically in the office of the tender inviting authority.

Page 12 of 51

T.S./JE Plg

C ... Nil I Nil O Nil

- **14.** Online bid documents submitted by intending bidders shall be opened only of those bidders, who has submitted prescribed EMD, and other documents scanned and uploaded are found in order.
- **15.** Those contractors not registered on the website mentioned above, are required to get registered beforehand. Bidders should refer "Instruction for Online Bid Submission" given earlier for further assistance.
- **16.** When bids are invited in two / three stages systems and if it is desired to submit revised financial bid it shall be mandatory to submit revised financial bid. If not submitted, then the bid submitted earlier shall become invalid.
- **17.** The department reserves the right to reject any prospective application without assigning any reason and to restrict the list of qualified contractors to any number deemed suitable by it, if too many bids are received satisfying the laid down criterion.
- **18.** Contractors must ensure to quote rate of each item.
- 19. The bid submitted shall become invalid if:
 - a. The bidder is found ineligible.
 - b. The bidder does not upload scanned copies of all the documents stipulated in the bid document.
 - c. If any discrepancy is noticed between the documents as uploaded at the time of submission of bid and hard copies as submitted physically by the lowest bidder in the office of bid opening / accepting authority.
 - d. If a tenderer quotes nil rates against each item in item rate tender or does not quote any percentage above/below on the total amount of the tender or any section / sub head in percentage rate tender, the tender shall be treated as invalid and will not be considered as lowest tenderer.
 - e. EMD not deposited / submitted as specified.
- 20. Equipment to be supplied shall satisfy Class-1 criteria. 'Class 1 Local Supplier' means a supplier or service provider, whose goods, services or works offered for procurement has local content equal to or more than 50% as defined under Order No. P-45021/2/2017-PP(BE-II) dated 04-06-2020 issued by Department for Promotion of Industry and Internal Trade (Public Procurement Section), Ministry of Commerce and Industry, Govt of India.
 - a. 'Local Content' means the amount of value added in India which shall unless and otherwise prescribed by the nodal ministry, be the total value of the item procured (excluding net domestic indirect taxes) minus the value of imported content in the item (including all domestic duties) as a proportion of the total value, in percent.
 - b. For the purpose of verification of 'Local Content', the Class-1 Local Supplier / Service Provider at the time of bidding, tender or solicitation shall be required to indicate percentage of local content and provide self-certification that the items offered meet the local content requirement for Class – 1 Local Supplier. They shall also give details of the location(s) at which the local value addition is made.
 - c. In cases of procurement for a value in excess of 10 crore, the Class 1 Local Supplier shall be required to provide a certificate from the statutory auditor or cost auditor of the company (in case of the companies) or from a practicing cost accountant or practicing chartered

C ... Nil I Nil O Nil

Page 13 of 51

accountant (in respect of suppliers other than companies) giving the percentage of local content.

- d. Nodal Ministries may constitute committees with internal and external experts for independent verification of self-certifications and auditor's / accountant's certificates on random basis and in the case of complaints.
- e. False declarations will be in breach of Code of Integrity under rule 175(1)(i)(h) of the General Financial Rules for which a bidder or its successors can be debarred for upto two years as per Rule 151 (iii) of the General Financial Rules along with such other actions as may be permissible under law.

List of MANDATORY DOCUMENTS to be scanned and uploaded within the period of bid submission:

C ... Nil I Nil O Nil

Page 14 of 51

T.S./JE Plg

IIT Delhi

Sr. No.	:	Details of Document
1	:	Annexure – 1 duly filled in and got signed by the bidder
2	:	Annexure – 2 (Technical details as desired) duly filled and signed by the bidder
3	:	 Proof of online EMD deposit / Scanned copy of DD / FDR submission (favouring 'Registrar, IIT Delhi') a. The following undertaking on firm's letter head shall be uploaded by the bidder if scanned copy of DD/FDR is uploaded by the bidder: "The exact physical EMD (as uploaded) shall be deposited by me / us with the authority inviting tender, in case I / we become the lowest tenderer within a week of the opening of financial bid, otherwise, IITD may reject the tender and also take actions to debar me / us from tendering in any form in IIT Delhi."
4	:	Certificate of work experience as desired (vide clauses 3 to 7 above)
5	:	Certificate of GST Registration, if already obtained by the bidder.
		If the bidder has not obtained GST registration as applicable, then h shall scan and upload following undertaking alongwith bid documents "If work is awarded to me, I/we shall obtain GST registration certificate a applicable within one month from the date of award letter or before release of any payment by IIT Delhi, whichever is earlier, failing which I/we shall b responsible for any delay in payments which will be due towards me/us of account of the work executed and/or for any action taken by IIT Delhi or GS department in this regard."
6	:	Affidavit as per provision of the clause 1.3.2 of IITD-6 vide page 13 (To be submitted on stamp paper (not less than rupees ten) and date of affidavit an <u>purchase</u> of stamp paper shall not be earlier than the publication of NIT. <u>Name of work</u> shall invariably be written on the <u>1st page of the Stamp</u> <u>Paper</u>)
7	:	Acceptance to execute INTEGRITY PACT (see integrity pact)
8	:	IITD 7 / 8 duly signed
9	:	EPFO & ESIC registration with upto date challan (challan shall be not older than or month from the month on which the tender is invited)
10	:	Certification of concerned OEM for the purpose of verification of 'Local Content (refer clause 20 above) the 'Class-1 Local Supplier / Service Provider' indicating -
		a. Percentage of local content

C ... Nil I Nil O Nil

Page 15 of 51

T.S./JE Plg

AC Division		IIT Delhi
		 b. Items offered meet the local content requirement for 'Class – 1 Local Supplier' c. Details of the location(s) at which the local value addition is made
11	:	Valid Electrical Licence in the name of the contractor. <i>if the bidder does not possess electrical licence in his own name, he shall have to submit an undertaking on their letter head and</i> the bidder shall scan and upload following undertaking along with other bid documents.
		a. "I/We undertake that, if I/we do not possess in my/our name a valid electrical license as required, I/we shall associate an agency having such a licence for execution of work which requires such a licence".
12	:	Any other document as specified

Note:

- a. Hard copies of documents are to be submitted as per clause 9.1 of IITD-6
- b. Original copies of documents are to be submitted for verifications as and when demanded by the tender inviting authority
- c. Bidders are advised to keep the Original Affidavit, EMD (if not deposited online) 'as it is' in safe custody till finalisation of bid

Assistant Executive Engineer in-charge, AC Division For & on Behalf of BOG, IIT Delhi

CPWD/IITD - 6

Page 16 of 51

C ... Nil I Nil O Nil

T.S./JE Plg

llT Delhi

INDIAN INSTITUTE OF TECHNOLOGY DELHI NOTICE INVITING E-TENDER

- 1.0 Item rate tenders are invited on behalf of The Board of Governors, IIT Delhi, Hauz Khas, New Delhi - 110016 from firms / contractors of repute in two bid system as per details given below for the work of SITC of Split & WAC Units at different places in IIT Delhi (ACCR 03 May 2024)
- 1.1 The work is estimated to cost **Rs.43,60,259.00.** This estimate, however, is given merely as a rough guide.
- 1.2 Intending bidder is eligible to submit the bid provided he has definite proof from the appropriate authority, which shall be to the satisfaction of the competent authority, of having satisfactorily completed similar works of magnitude specified below:-
- 1.2.1 Criteria of eligibility for submission of bid documents: Conditions for intending bidders / contractors
- 1.2.1.1 **Three** similar works each costing not less than **Rs.17,44,000.00**, or **two** similar works each costing not less than **Rs.26,16,000.00**, or one similar work costing not less than **Rs.34,88,000.00** in last 7 years ending last day of the month previous to the one in which tenders are invited. The value of executed work shall be brought to current costing level by enhancing the actual value of work at simple rate of 7% per annum; calculated from the date of completion to last date of submission of bid.
- 1.2.2 To become eligible for issue of bid, the bidders shall have to furnish an affidavit as under: - "I / We undertake and confirm that eligible similar works(s) has/have not been got executed through another contractor on back-to-back basis. Further that, if such a violation comes to the notice of Department, then I / we shall be debarred for bidding in IIT Delhi in future forever. Also, if such a violation comes to the notice of Department before date of start of work, the Engineer-in-Charge shall be free to forfeit the entire amount of Earnest Money Deposit/Performance Guarantee (Scanned copy to be uploaded at the time of submission of bid)"
- **2.0** Agreement shall be drawn with the successful bidders on prescribed Form No. IITD 7/8 which is available as IIT Delhi Publication. Bidders shall quote their rates as per various terms and conditions of the said form which will form part of the agreement.
- **3.0** The time allowed for carrying out the work will be **50 days** from the date of start as defined in schedule 'F' or from the first date of handing over of the site, whichever is later, in accordance with the phasing, if any, indicated in the bid documents.
- 4.0 The site for the work is available.
- **5.0** The bid document consisting of plans, specifications, the schedule of quantities of various types of items to be executed and the set of terms and conditions of the contract to be complied with and other necessary documents except Standard General Conditions of Contract Form can be seen from the web Site **e-procure.gov.in**.
- 6.0 After submission of the bid the contractor can re-submit revised bid any number of times

C ... Nil I Nil O Nil

Page 17 of 51

but before last time and date of submission of tender as notified.

- **7.0** While submitting the revised bid, contractor can revise the rate of one or more item(s) any number of times (he need not re-enter rate of all the items) but before last time and date of submission of tender as notified.
- **8.0** If it is desired to submit revised financial bid then it shall be mandatory to submit revised financial bid. If not submitted then the tender submitted earlier shall become invalid.
- **9.0** EMD shall have to be deposited / submitted as stipulated in the schedule of the NIT.
- 9.1 Copy of all 'mandatory documents' and other documents as specified in the press notice shall be scanned and uploaded to the e-tendering website within the period of bid submission. *However, original affidavit, EMD (if not deposited online) and certified copies of all the scanned and uploaded documents as specified in press notice shall have to be submitted by the lowest bidder only within a week physically in the office of tender opening authority. Original copies of other documents are also to be shown for scrutiny and verifications by the tender opening / accepting authority.*
- 10.0 The bid submitted shall become invalid if:
- 10.1 The bidder is found ineligible.
- 10.2 The bidder does not upload scanned copies of all the documents stipulated in the bid document.
- 10.3 If any discrepancy is noticed between the documents as uploaded at the time of submission of bid and hard copies as submitted physically by the lowest bidder in the office of bid opening / accepting authority.
- 10.4 If a tenderer quotes nil rates against each item in item rate tender or does not quote any percentage above/below on the total amount of the tender or any section / sub head in percentage rate tender, the tender shall be treated as invalid and will not be considered as lowest tenderer.
- 10.5 EMD not deposited / submitted as specified.
- 11.0 The contractor whose bid is accepted will be required to furnish **performance guarantee** of 5% (Five Percent) of the bid amount within the period specified in Schedule F. This guarantee shall be in the form of Insurance Surety Bonds, Account Payee Demand Draft, Fixed Deposit Receipt or Bank Guarantee from any of the Commercial Banks in accordance with the prescribed form. In case the contractor fails to deposit the said performance guarantee within the period as indicated in Schedule 'F', including the extended period if any, the Earnest Money deposited by the contractor shall be forfeited automatically without any notice to the contractor. The earnest money deposited along with bid shall be returned after receiving the aforesaid performance guarantee.
- 12.0 Intending Bidders are advised to inspect and examine the site and its surroundings and satisfy themselves before submitting their bids as to the nature of the ground and subsoil (so far as is practicable), the form and nature of the site, the means of access to the site, the accommodation they may require and in general shall themselves obtain all necessary information as to risks, contingencies and other circumstances which may influence or affect their bid. A bidder shall be deemed to have full knowledge of the site whether he inspects it or not and no extra charge consequent on any misunderstanding or otherwise shall be allowed. The bidders shall be responsible for arranging and maintaining at his own cost all

Page 18 of 51

C ... Nil I Nil O Nil

materials, tools & plants, water, electricity access, facilities for workers and all other services required for executing the work unless otherwise specifically provided for in the contract documents. Submission of a bid by a bidder implies that he has read this notice and all other contract documents and has made himself aware of the scope and specifications of the work to be done and of conditions and rates at which stores, tools and plant, etc. will be issued to him by the Government and local conditions and other factors having a bearing on the execution of the work.

- **13.0** The competent authority on behalf of the Board of Governors does not bind itself to accept the lowest or any other bid and reserves to itself the authority to reject any or all the bids received without the assignment of any reason. All bids in which any of the prescribed condition is not fulfilled or any condition including that of conditional rebate is put forth by the bidder shall be summarily rejected.
- **14.0** Canvassing whether directly or indirectly, in connection with bidders is strictly prohibited and the bids submitted by the contractors who resort to canvassing will be liable for rejection.
- **15.0** The competent authority on behalf of the Board of Governors reserves to himself the right of accepting the whole or any part of the bid and the bidder shall be bound to perform the same at the rate quoted.
- 16.0 The contractor shall not be permitted to bid for works in the IITD responsible for award and execution of contracts, in which his near relative is posted a Divisional Accountant or as an officer in any capacity between the grades of Superintending Engineer and Junior Engineer (both inclusive). He shall also intimate the names of persons who are working with him in any capacity or are subsequently employed by him and who are near relatives to any Gazetted officer in the IIT Delhi. Any breach of this condition by the contractor would render him liable to be debarred from bidding process in future in IIT Delhi.
- 17.0 No Engineer of Gazetted rank or other Gazetted Officer employed in Engineering or Administrative duties in an Engineering Department of the Government of India is allowed to work as a contractor for a period of one year after his retirement from Government service, without the prior permission of the Government of India in writing. This contract liable to be cancelled, if, either the contractor or any of his employees is found any time to be such a person who had not obtained the permission of the Government of India as aforesaid before submission of the bid or engagement in the contractor's service.
- 18.0 The bids for the work shall remain open for acceptance for a period of 75 (seventy five) days from the date of opening of technical bids. Further
- 18.1 If any tenderer withdraws his tender or makes any modification in the terms & conditions of the tender which is not acceptable to the department within 7 days after last date of submission of bids, then the Government shall without prejudice to any other right or remedy, be at liberty to forfeit 50% of the earnest money absolutely irrespective of letter of acceptance for the work is issued or not.
- 18.2 If any tenderer withdraws his tender or makes any modification in the terms & conditions of the tender which is not acceptable to the department after expiry of 7 days after last date of submission of bids, then the Government shall without prejudice to any other right or remedy, be at liberty to forfeit 100% of the earnest money absolutely irrespective of

C ... Nil I Nil O Nil

Page 19 of 51

letter of acceptance for the work is issued or not.

- 18.3 In case of forfeiture of earnest money as prescribed in para (18.1) and (18.2) above, the bidders shall not be allowed to participate in the rebidding process of the same work.
- **19.0** This notice inviting bid shall form a part of the contract document. The successful bidder / contractor, on acceptance of his bid by the Accepting Authority shall **within fifteen days** from the stipulated date of start of the work, sign the contract consisting of:-
- 19.1 The Notice Inviting Bid, all the documents including additional conditions, specifications and drawings, if any, forming part of the bid as uploaded at the time of invitation of bid and the rates quoted online at the time of submission of bid and acceptance thereof together with any correspondence leading thereto.
- 19.2 Standard IITD Form –7/8 or other Standard IITD Form as applicable.
- 20.0 Integrity Pact: The contractor shall download the Integrity Pact, which is a part of tender documents, affix his signature and upload the same while submitting online bids. In the event of his failure to sign and upload the Integrity Pact along with other bid documents, his bid shall be rejected.

INTEGRITY PACT

То

·····,

Sub: NIT No. 616/30/IITD/AC/2024-25 for the work of "SITC of Split & WAC Units at different places in IIT Delhi (ACCR 03 May 2024)"

Dear Sir,

It is hereby declared that IIT Delhi (IITD) is committed to follow the principle of transparency, equity and competitiveness in public procurement.

The subject Notice Inviting Tender (NIT) is an invitation to offer made on the condition that the Bidder will sign the Integrity Agreement, which is an integral part of the tender/bid documents, failing which the tender/bidder will stand disqualified from the tendering process and the bid of the bidder would be summarily rejected.

This declaration shall form part and parcel of the Integrity Agreement and signing of the same shall be deemed as acceptance and signing of the Integrity Agreement on behalf of the IITD.

Yours faithfully,

Assistant Executive Engineer in-charge, AC Division For & on Behalf of BOG, IIT Delhi

C ... Nil I Nil O Nil

Page 21 of 51

T.S./JE Plg

IIT Delhi

[TO BE SUBMITTED DULY SIGNED BY THE BIDDER ALONGWITH BID DOCUMENTS]

То

Assistant Executive Engineer-in-charge, AC Division, IIT Delhi, Hauz Khas, New Delhi – 110016

Subject: Submission of Bid for the work of "SITC of Split & WAC Units at different places in IIT Delhi (ACCR 03 May 2024)"

Dear Sir,

I / We acknowledge that IIT Delhi is committed to follow the principles thereof as enumerated in the Integrity Agreement enclosed with the tender/bid document.

I / We agree that the Notice Inviting Tender (NIT) is an invitation to offer made on the condition that I / We will sign the enclosed integrity Agreement, which is an integral part of tender / bid documents, failing which I / We will stand disqualified from the tendering process. I / We acknowledge that THE MAKING OF THE BID SHALL BE REGARDED AS AN UNCONDITIONAL AND ABSOLUTE ACCEPTANCE of this condition of the NIT.

I / We confirm acceptance and compliance with the Integrity Agreement in letter and spirit and further agree that execution of the said Integrity Agreement shall be separate and distinct from the main contract, which will come into existence when tender/bid is finally accepted by IITD. I / We acknowledge and accept the duration of the Integrity Agreement, which shall be in the line with Article 1 of the enclosed Integrity Agreement.

I / We acknowledge that in the event of my/our failure to sign and accept the Integrity Agreement, while submitting the tender/bid, IITD shall have unqualified, absolute and unfettered right to disqualify the tenderer /bidder and reject the tender/bid is accordance with terms and conditions of the tender/bid.

Yours faithfully,

(Duly signed by authorized signatory of the Bidder)

C ... Nil I Nil O Nil

Page 22 of 51

T.S./JE Plg

AC Division	IIT Delhi					
(To be signed by the bidder and same signatory competent / authorized to sign the relevant contract on behalf of IITD)						
INTEGRITY AGREEMENT						
This Integrity Agreement is made at on this o 20	day of					
BETWEEN						
The Board of Governors, IIT Delhi, Hauz Khas, New Delhi - 16 represented through Assistant Executive Engineer-in-charge, AC Division, IIT Delhi, (Hereinafter referred as the 'Principal/Owner', 'Principal/Owner', which expression shall unless repugnant to the meaning or context hereof include its successors and permitted assigns)						
AND						
(Name and Address of the Individual/firm/Company)						
Through(Hereinafter referred	••••••					
(Details of duly authorized signatory) to as the " Bidder/Contractor " and which expression shall unless repugnant to the mear hereof include its successors and permitted assigns)	ning or context					

PREAMBLE

WHEREAS the Principal / Owner has floated the Tender (NIT No. 616/30/IITD/AC/2024-25) (hereinafter referred to as "Tender/Bid") and intends to award, under laid down organizational procedure, contract for "SITC of Split & WAC Units at different places in IIT Delhi (ACCR 03 May 2024)" (Name of work) hereinafter referred to as the "Contract".

AND WHEREAS the Principal/Owner values full compliance with all relevant laws of the land, rules, regulations, economic use of resources and of fairness/transparency in its relation with its Bidder(s) and Contractor(s) AND WHEREAS to meet the purpose aforesaid both the parties have agreed to enter into this Integrity Agreement (hereinafter referred to as "Integrity Pact" or "Pact"), the terms and conditions of which shall also be read as integral part and parcel of the Tender/Bid documents and Contract between the parties.

NOW, THEREFORE, in consideration of mutual covenants contained in this Pact, the parties hereby agree as follows and this Pact witnesses as under:

ARTICLE 1: COMMITMENT OF THE PRINCIPAL / OWNER

C ... Nil I Nil O Nil

T.S./JE Plg

AEE-in-charge AC Division

Page 23 of 51

- 1. The Principal/Owner commits itself to take all measures necessary to prevent corruption and to observe the following principles:
 - **1.1.** No employee of the Principal / Owner, personally or through any of his / her family members, will in connection with the Tender, or the execution of the Contract, demand, take a promise for or accept, for self or third person, any material or immaterial benefit which the person is not legally entitled to.
 - 1.1.1. The Principal/Owner will, during the Tender process, treat all Bidder(s) with equity and reason. The Principal/Owner will, in particular, before and during the Tender process, provide to all Bidder(s) the same information and will not provide to any Bidder(s) confidential / additional information through which the Bidder(s) could obtain an advantage in relation to the Tender process or the Contract execution.
 - **1.1.2.** The Principal/Owner shall Endeavour to exclude from the Tender process any person, whose conduct in the past has been of biased nature.
- 2. If the Principal/Owner obtains information on the conduct of any of its employees which is a criminal offence under the Indian Penal code (IPC)/Prevention of Corruption Act, 1988 (PoC Act) or is in violation of the principles herein mentioned or if there be a substantive suspicion in this regard, the Principal/Owner will inform the Chief Vigilance Officer and in addition can also initiate disciplinary actions as per its internal laid down policies and procedures.

ARTICLE 2: COMMITMENT OF THE BIDDER(S) / CONTRACTOR(S)

- It is required that each Bidder/Contractor (including their respective officers, employees and agents) adhere to the highest ethical standards, and report to the Government / Department all suspected acts of fraud or corruption or coercion or collusion of which it has knowledge or becomes aware, during the tendering process and throughout the negotiation or award of a contract.
- 2. The Bidder(s)/Contractor(s) commits himself to take all measures necessary to prevent corruption. He commits himself to observe the following principles during his participation in the Tender process and during the Contract execution:
 - 2.1. The Bidder(s)/Contractor(s) will not, directly or through any other person or firm, offer, promise or give to any of the Principal/Owner's employees involved in the Tender process or execution of the Contract or to any third person any material or other benefit which he/she is not legally entitled to, in order to obtain in exchange any advantage of any kind whatsoever during the Tender process or during the execution of the Contract.
 - **2.2.** The Bidder(s)/Contractor(s) will not enter with other Bidder(s) into any undisclosed agreement or understanding, whether formal or informal. This applies in particular to prices, specifications, certifications, subsidiary contracts, submission or non-submission of bids or any other actions to restrict competitiveness or to cartelize in the bidding process.
 - **2.3.** The Bidder(s) / Contractor(s) will not commit any offence under the relevant IPC/PoC Act. Further the Bidder(s) / Contractor(s) will not use improperly, (for the purpose of competition or personal gain), or pass on to others, any information or documents provided by the Principal / Owner as part of the business relationship, regarding plans, technical proposals and business details, including information contained or transmitted electronically.
 - 2.4. The Bidder(s) / Contractor(s) of foreign origin shall disclose the names and addresses of agents / representatives in India, if any. Similarly Bidder(s) / Contractor(s) of Indian Nationality shall disclose names and addresses of foreign agents/representatives, if any. Either the Indian agent on behalf of the foreign principal or the foreign principal directly could bid in a tender

C ... Nil I Nil O Nil

Page 24 of 51

but not both. Further, in cases where an agent participate in a tender on behalf of one manufacturer, he shall not be allowed to quote on behalf of another manufacturer along with the first manufacturer in a subsequent/parallel tender for the same item.

- **2.5.** The Bidder(s)/Contractor(s) will, when presenting his bid, disclose any and all payments he has made, is committed to or intends to make to agents, brokers or any other intermediaries in connection with the award of the Contract.
- **3.** The Bidder(s)/Contractor(s) will not instigate third persons to commit offences outlined above or be an accessory to such offences.
- 4. The Bidder(s)/Contractor(s) will not, directly or through any other person or firm indulge in fraudulent practices means a wilful misrepresentation or omission of facts or submission of fake/forged documents in order to induce public official to act in reliance thereof, with the purpose of obtaining unjust advantage by or causing damage to justified interest of others and/or to influence the procurement process to the detriment of the Government interests.
- 5. The Bidder(s)/Contractor(s) will not, directly or through any other person or firm use Coercive Practices (means the act of obtaining something, compelling an action or influencing a decision through intimidation, threat or the use of force directly or indirectly, where potential or actual injury may befall upon a person, his/ her reputation or property to influence their participation in the tendering process).

ARTICLE 3: CONSEQUENCES OF BREACH

Without prejudice to any rights that may be available to the Principal / Owner under law or the Contract or its established policies and laid down procedures, the Principal/Owner shall have the following rights in case of breach of this Integrity Pact by the Bidder(s)/Contractor(s) and the Bidder/ Contractor accepts and undertakes to respect and uphold the Principal/Owner's absolute right:

- 1. If the Bidder(s)/Contractor(s), either before award or during execution of Contract has committed a transgression through a violation of Article 2 above or in any other form, such as to put his reliability or credibility in question, the Principal/Owner after giving 14 days' notice to the contractor shall have powers to disqualify the Bidder(s)/Contractor(s) from the Tender process or terminate/determine the Contract, if already executed or exclude the Bidder/Contractor from future contract award processes. The imposition and duration of the exclusion will be determined by the severity of transgression and determined by the Principal/Owner. Such exclusion may be forever or for a limited period as decided by the Principal/Owner.
- 2. Forfeiture of EMD/Performance Guarantee/Security Deposit: If the Principal/Owner has disqualified the Bidder(s) from the Tender process prior to the award of the Contract or terminated/determined the Contract or has accrued the right to terminate/determine the Contract according to Article 3(1), the Principal/Owner apart from exercising any legal rights that may have accrued to the Principal/Owner, may in its considered opinion forfeit the entire amount of Earnest Money Deposit, Performance Guarantee and Security Deposit of the Bidder/Contractor.
- **3.** Criminal Liability: If the Principal/Owner obtains knowledge of conduct a Bidder or Contractor, or of an employee or a representative or an associate of a Bidder or Contractor which constitutes corruption within the meaning of IPC Act, or if the Principal / Owner has substantive suspicion in this regard, the Principal/Owner will inform the same to law enforcing agencies for further investigation.

ARTICLE 4: PREVIOUS TRANSGRESSION

C ... Nil I Nil O Nil

Page 25 of 51

- 1. The Bidder declares that no previous transgressions occurred in the last 5 years with any other Company in any country confirming to the anticorruption approach or with Central Government or State Government or any other Central/State Public Sector Enterprises in India that could justify his exclusion from the Tender process.
- 2. If the Bidder makes incorrect statement on this subject, he can be disqualified from the Tender process or action can be taken for banning of business dealings/ holiday listing of the Bidder/Contractor as deemed fit by the Principal/ Owner.
- **3.** If the Bidder/Contractor can prove that he has resorted / recouped the damage caused by him and has installed a suitable corruption prevention system, the Principal/Owner may, at its own discretion, revoke the exclusion prematurely.

ARTICLE 5: EQUAL TREATMENT OF ALL BIDDERS/CONTRACTORS/SUBCONTRACTORS

- 1. The Bidder(s)/Contractor(s) undertake(s) to demand from all subcontractors a commitment in conformity with this Integrity Pact. The Bidder/Contractor shall be responsible for any violation(s) of the principles laid down in this agreement/Pact by any of its Sub-contractors/sub-vendors.
- 2. The Principal/Owner will enter into Pacts on identical terms as this one with all Bidders and Contractors.
- **3.** The Principal/Owner will disqualify Bidders, who do not submit, the duly signed Pact between the Principal/Owner and the bidder, along with the Tender or violate its provisions at any stage of the Tender process, from the Tender process.

ARTICLE 6: DURATION OF THE PACT

- 1. This Pact begins when both the parties have legally signed it. It expires for the Contractor/Vendor 6 months after the completion of work under the contract or till the continuation of defect liability period, whichever is more and for all other bidders, till the Contract has been awarded.
- 2. If any claim is made/lodged during the time, the same shall be binding and continue to be valid despite the lapse of this Pacts as specified above, unless it is discharged/determined by the Competent Authority of IT Delhi.

ARTICLE 7: OTHER PROVISIONS

- 1. This Pact is subject to Indian Law, place of performance and jurisdiction is the Head Quarters of the Division of the Principal/Owner, who has floated the Tender.
- 2. Changes and supplements need to be made in writing. Side agreements have not been made.
- **3.** If the Contractor is a partnership or a consortium, this Pact must be signed by all the partners or by one or more partner holding power of attorney signed by all partners and consortium members. In case of a Company, the Pact must be signed by a representative duly authorized by Board Resolution.
- **4.** Should one or several provisions of this Pact turn out to be invalid; the remainder of this Pact remains valid. In this case, the parties will strive to come to an agreement to their original intensions.
- 5. It is agreed term and condition that any dispute or difference arising between the parties with regard to the terms of this Integrity Agreement / Pact, any action taken by the Owner/Principal in accordance with this Integrity Agreement/ Pact or interpretation thereof shall not be subject to

C ... Nil I Nil O Nil

Page 26 of 51

arbitration.

ARTICLE 8: LEGAL AND PRIOR RIGHTS

 All rights and remedies of the parties hereto shall be in addition to all the other legal rights and remedies belonging to such parties under the Contract and/or law and the same shall be deemed to be cumulative and not alternative to such legal rights and remedies aforesaid. For the sake of brevity, both the Parties agree that this Integrity Pact will have precedence over the Tender/Contact documents with regard any of the provisions covered under this Integrity Pact.

IN WITNESS WHEREOF the parties have signed and executed this Integrity Pact at the place and date first above mentioned in the presence of following witnesses:

 (For and on behalf of Principal / Owner)	
(For and on behalf of Bidder / Contractor)	
WITNESSES:	
1	
(signature, name and address)	
2.	
(signature, name and address)	
Place:	Dated :

C ... Nil I Nil O Nil

IIT Delhi

<u>CPWD/IITD - 7/8</u>

INDIAN INSTITUTE OF TECHNOLOGY DELHI HAUZ KHAS, NEW DELHI - 110016

Percentage Rate Tender / Item Rate Tender & Contract for Works

Tender for the work of "SITC of Split & WAC Units at different places in IIT Delhi (ACCR 03 May 2024)"

1. To be submitted online by Upto 3 PM of 27-06-2024

2. To be opened on 28-06-2024 after 3 PM online

e-TENDER

I / We have read and examined the Notice Inviting Tender, schedule, A, B, C, D, E & F, Specifications applicable, Drawings & Designs, General Rules and Directions, Conditions of Contract, Clauses of Contract, Special conditions, Schedule of Rate & other documents and Rules referred to in the conditions of contract and all other contents in the tender document for the work.

I / We hereby tender for the execution of the work specified for the Board of Governors, IIT Delhi within the time specified in Schedule 'F' viz., schedule of quantities and in accordance in all respect with the specifications, designs, drawing and instructions in writing referred to in Rule-1 of General Rules and Directions and in Clause 11 of the Conditions of contract and with such materials as are provided for, by, and in respect of accordance with, such conditions so far as applicable.

We agree to keep the tender open for ninety (90) days from the due date of its opening / ninety days from the date of opening of financial bid in case tenders are invited on 2/3 envelop system (strike out as the case may be) and not to make any modification in its terms and conditions.

A sum of **Rs. 87,205.00** is hereby deposited in IIT Delhi Revenue Account No. 10773572622 as earnest money / **A Demand Draft** / **FDR of Rs. 87,205.00** favouring Registrar, IIT Delhi has been scanned and uploaded with the Technical Bid. If I / We, fail to furnish the prescribed performance guarantee within prescribed period I / We agree that the said The Board of Governors, IIT Delhi, Hauz Khas, New Delhi - 16 or his successors, in office shall without prejudice to any other right or remedy, be at liberty to forfeit the said earnest money absolutely. Further, if I / We fail to commence the work as specified, I / We agree that The Board of Governors, IIT Delhi, Hauz Khas, New Delhi - 16 or the successors in office shall without prejudice to any other right or remedy as specified, I / We agree that The Board of Governors, IIT Delhi, Hauz Khas, New Delhi - 16 or the successors in office shall without prejudice to any other right or remedy available in law, be at liberty to forfeit the said earnest money and the performance guarantee absolutely, otherwise the said earnest money shall be retained by him towards security deposit to execute all the works referred to in the tender documents upon the terms and conditions contained or referred to those in excess of that limit at the rates to be determined in accordance with the provision contained in Clause 12.2 and 12.3 of the tender form. Further, I / We agree that in case of forfeiture of Earnest Money & Performance Guarantee as aforesaid I / We shall be debarred for participation in the re-tendering process of the work.

I / We undertake and confirm that eligible similar work(s) has/have not been got executed through another contractor on back to back basis. Further that, if such a violation comes to the notice

C ... Nil I Nil O Nil

AEE-in-charge AC Division

Page 28 of 51

IIT Delhi

of Department, then I / We shall be debarred for tendering in IIT Delhi in future forever. Also, if such a violation comes to the notice of Department before date of start of work, the Engineer-in-Charge shall be free to forfeit the entire amount of Earnest Money Deposit/Performance Guarantee.

I / We hereby declare that I / We shall treat the tender documents drawings and other records connected with the work as secret/confidential documents and shall not communicate information/derived there from to any person other than a person to whom I / We am/are authorized to communicate the same or use the information in any manner prejudicial to the safety of the State.

Dated:

Signature of Contractor

Postal Address

Witness:

Address:

Occupation:

ACCEPTANCE

The above	tender (as modified	by you as provi	ded in the letters m	entioned hereunder) is
accepted by me for	an on behalf of The E	Board of Governo	ors, IIT Delhi, Hauz Kha	as, New Delhi - 110016
for	a		sum	of
(Rupees).

The letters referred to below shall form part of this contract agreement:-

- (a) (b)
- (c)

For & on behalf of Board of Governors, IIT Delhi

Signature

Designation

Dated:

PROFORMA OF SCHEDULES

C ... Nil I Nil O Nil

Page 29 of 51

T.S./JE Plg

IIT Delhi

SCHEDULE "A"

Schedule of Quantities (PWD-3)

SCHEDULE "D"

Extra schedule for specific requirements / documents for the work, if any.

----- NIL -----

SCHEDULE "E"

Reference to General Conditions of Contract: GCC of Maintenance Work 2023 published by CPWD as amended up to last date of submission of bid.

1.	Name of work	:	SITC of Split & WAC Units at different places in II Delhi (ACCR 03 May 2024)					
2.	Estimated cost of work (₹)	:	43,60,259.00					
3.	Earnest Money (₹)	:	87,205.00 (to be refunded after receiving performance guarantee)					
4.	Performance Guarantee	:	5 percent of tendered value					
5.	Security Deposit	÷	2.5% (percent) of tendered value					

SCHEDULE "F"

GENERAL RULES & DIRECTIONS:

Officer inviting tender	:	Assistant Executive Engineer in-charge, AC Division
Maximum percentage for quantity of items of work to be executed beyond which rates are to be determined in accordance with Clauses 12.2 & 12.3		See below

DEFINITIONS:

2 (V)	Engineer-in-charge	:	Assistant Executive Engineer in-charge, AC Division
-------	--------------------	---	--

C ... Nil I Nil O Nil

Page 30 of 51

T.S./JE Plg

2 (viii)	Accepting authority	:	Assistant Executive Engineer in-charge, AC Division
2 (x)	Percentage on cost of materials and labour to cover all overheads and profits	:	15 percent
2 (xi)	Standard Schedule of Rates	:	Market, DSR
2 (xii)	Department	:	Estate & Works, IIT Delhi
9 (ii)	Reference to General condition of contract	:	CPWD / IITD Form 7 / 8 as modified and corrected upto date, GCC 2020 for Maintenance work of CPWD with latest modifications

CLAUSE 1

i)	Time allowed for submission of Performance Guarantee from the date of issue of letter of acceptance	:	15 days
ii)	Maximum allowable extension beyond the period provided in (i) above with late fees @0.1% per day of performance guarantee	:	10 days

CLAUSE 2

(i)	Authority for fixing compensation under Clause 2	:	Institute Engineer

CLAUSE 2A

(i)	Whether Clause 2A shall be applicable	:	No

CLAUSE 5

(i)	Number of days from the date of issue of letter of : 10 days
	acceptance for reckoning date of start

TABLE OF MILESTONE(S):

C ... Nil I Nil O Nil

Page 31 of 51

T.S./JE Plg

llT Delhi

Sr. No.	Description of Milestone (physical)	Time allowed in days (from date of start)	Amount to be with-held in case of non-achievement of milestone
(1)	(2)	(3)	(4)
	NOT SPECIFIED		

Time allowed for execution of work	:	50 days

Authority to decide:	Extension of time	:	Engineer-in-charge
	Rescheduling of milestones	:	Institute Engineer
	Shifting of date of start in case of delay in handing over of site	Ċ	Engineer-in-charge

CLAUSE 5

Clause applicable 5 / 5A	:	5

CLAUSE 6

	1	
MB applicable: Computerised Measurement Book (CMB) /	•	СМВ
	•	GIID
Electronic Measurement Book (EMB)		
Lieutonic Measurement Dook (Lind)		

CLAUSE 7

Gross work to be done together with net payment /	:	
adjustment of advances for materials collected, if any, since		10 Lakhs
the last such payment for being eligible to interim payment		

CLAUSE 7A

Whether Clause 7A shall be applicable	: No	

CLAUSE 10A

C ... Nil I Nil O Nil

Page 32 of 51

T.S./JE Plg

	List of testing equipment to be provided by the contractor at site							
1	500 Volt Megger	2	Digital Multimeter	3	NIL			
4	NIL	5	NIL	6	NIL			

CLAUSE 10B (ii)

Whether Clause 10 B (ii) shall be applicable (Yes /	:	No
No)		

CLAUSE 10 C

ſ	Component of labour expressed as percent of value of work	:	15 Percent

CLAUSE 10CC

Whether Clause 10CC shall be applicable	:	Not applicable

CLAUSE 11

Specification	to	be	followed	for	÷	CPWD	General	Specifications	for	Electrical
execution of v	vork						for HVAC nded upto	Work with othe	r rele	vant parts
						as ante		Juate		

CLAUSE 12

12.2	Deviation limit beyond which clauses 12.2 shall apply for building work / HVAC work	:	100%
------	---	---	------

CLAUSE 16

Competent authority for deciding reduced rates	:	Institute Engineer

CLAUSE 18

C ... Nil I Nil O Nil

Page 33 of 51

T.S./JE Plg

IIT Delhi

	List of mandatory machine	ry,	tools & plants to be deploye	ed I	by the contractor at site
1	NIL	2	NIL	3	NIL
4	NIL	5	NIL	6	NIL

CLAUSE 19C

Authority to decide penalty for each default	:	Engineer-in-charge
--	---	--------------------

CLAUSE 19D

Authority to decide penalty for each default	:	Engineer-in-charge

CLAUSE 19G

Authority to decide penalty for each default	:	: Engineer-in-charge	

CLAUSE 19K

Authority to decide penalty for each default	: Not ap	Not applicable		

CLAUSE 25

Constitution of Dispute Redressal Committee (DRC)

Conciliator	:	Associate Dean Infra
Arbitrator Appointing Authority	:	Director
Place of Arbitration	:	IIT Delhi

C ... Nil

I Nil

O Nil

Assistant Engineers retired from Govt. / IIT Delhi services that are holding Diploma will be treated at par with Graduate Engineers. Diploma holder with minimum 10-year relevant experience with a reputed construction co. can be treated at par with Graduate Engineers for the purpose of such deployment subject to the condition that such diploma holders should not exceed 50% of requirement of degree engineers.

CLAUSE 38

Applicability of Clause 38		:	Not applicable

CLAUSE 32

Requirement of Technical Representative(s) and recovery rate

Sr. No.	Minimum qualification of Technical Representative	Discipline	Designation Principal Technical / Technical representative)	Minimum experience	Number	Rate at which shall be made contractor in th not fulfilling pi clause 3	from the ne event of rovision of												
			E)			Figures	Words												
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)												
1	Graduate	Electrical	Technical	2 years	1	Rs.15,000/-	Fifteen												
	or	or	Representative	Graduate		per month per	Thousand												
	Diploma	Mechanical		or		Representative													
	Engg.			5 years															
				Diploma															

Page 35 of 51

COMMERCIAL AND ADDITIONAL CONDITIONS

1. GENERAL

- 1.1. This specification covers supply and delivery of materials at site, all preparatory work assembly and installation, commissioning and putting into operation of Split/Window type AC units & final testing & commissioning at site.
- 1.2. Location: The equipments will be installed in in different Labs and offices at IIT Delhi
- 1.3. The work shall be executed as per CPWD General Specifications for Electrical Works Part-I (Int.) 2013, Part-II (Ext.) 1994, HVAC Work 2017, as amended upto date, relevant I.E. Rules, **BIS/IEC** and as per directions of Engineer-in-Charge. These additional specifications/conditions are to be read in conjunction with above and in case of variations; specifications given in these additional conditions shall apply. However, nothing extra shall be paid on account of these additional specification and conditions, as the same are to be read along with schedule of quantities for the work.
- **1.4.** The tenderer should in his own interest visit the site and get familiarized with the site conditions before tendering.
- **1.5.** No T&P shall be issued by the Department and nothing extra shall be paid on account of this.

2. COMMERCIAL CONDITIONS:

- **2.1. Type of contract:** The work to be awarded by this tender shall be treated as indivisible works contract.
- 2.2. Submission and opening of Tenders:
- 2.2.1. The tender is in two parts:
 - 2.2.1.1. Part-I -Technical cum Un-priced commercial Bid

2.2.1.2. Part-II-Price Bid

- **2.3.** The tender shall be submitted online, duly completed as per NIT conditions within period of bid submission.
- **2.4.** The tenderers are advised not to deviate from the technical specifications / item, commercial terms and conditions of NIT like terms of payment, guarantee, arbitration clause, escalation etc.
- **2.5.** Technical cum un-priced commercial bid only shall be opened on the due date and time in the presence of tenderers or their authorized representative who wish to remain present.
- **2.6.** Scrutiny/evaluation of the technical-cum-commercial bid shall be done by the department. In case, it is found that the technical-cum-commercial bid of a tenderer is not in line with NIT specifications/requirements and/or contains too many deviations, the department reserves the right to reject the technical bid of such firms(s) without making any reference to the tenderer(s).

C ... Nil I Nil O Nil

Page 36 of 51

- 2.7. Necessary clarifications required by the department shall have to be furnished by the tenderer within the time given by the department for the same. The tenderer will have to depute his representative to discuss with the officer(s) of the department as and when so desired. In case, in the opinion of the department a tenderer is taking undue long time in furnishing the desired clarifications, his bid will be rejected without making any reference.
- **2.8.** After obtaining clarification from all the tenders, the department will intimate the tenders whose technical cum commercial bids are acceptable.
- **2.9.** The price bids of only those tenderers shall be opened whose technical bids are found to be technically acceptable. The time and date of opening of price bid shall be fixed after the technical cum unpriced commercial bid is accepted and intimated to them by post/Fax/e-mail.
- **2.10.** The department reserves the right to reject any or all the price bids and call for fresh prices/tenders as the case may be without assigning any reason.

3. TERMS OF PAYMENTS

- 3.1. Payment shall be released after successful completion (Supply, Installation, Testing and satisfactory commissioning) of the work. However, R.A. bill may be preferred to the extent of 70% of Machines after initial inspection and delivery at site in good condition on prorata basis based on progress of overall work. Bidder should note that necessary documents (PAN card, cancelled cheque, GST Reg. proof and RTGS mandate form as per prescribed proforma of IIT Delhi) be submitted as soon as the work is awarded to them. Separate Contractor's Code shall be generated in IIT Delhi if the bidder is a new contractor to IIT Delhi ('Code' is perpetual in nature). Payment shall be processed after submission of Invoice and necessary documents / certificates (as mentioned in the NIT). There is a prevailing practice of pre-audit (for total tendered amount more than 6 lakhs) at IIT Delhi before releasing final payment. Bidder shall have to comply all necessary documents as outlined in the Contract as to be desired by the Auditor and or by the accountant. It may take one to two months in the whole process (from submission / acceptance of bill in CMB / MB by the contractor upto processing by Accounts section) to release payment subject to guick compliance of all submittals by the contractor. Applicable Taxes shall be got deducted from the bill as per prevailing orders of the Government. 'GST part of the bill' shall be released after submission of proof of payment of GST, i.e., B2B challan, etc. as may be, by the contractor.
- **3.2.** Income tax, GST, labour cess & other statutory deduction etc. shall be made at source as per the prevalent laws. The deduction of Security Deposit, Income Tax, etc., shall be done after calculation for the above due payment as per clause 3.1 above and net payment shall reduce accordingly.

4. AWARD OF WORK

4.1. Work shall be awarded to the successful bidder only after concurrence of the Auditor of the Internal Audit Section of the IIT Delhi as per extant Rules of the Institute.

5. SECURITY DEPOSIT

C ... Nil I Nil O Nil

Page 37 of 51

6. Security Deposit shall be deducted from each running bill to the extent of 5% of the gross amount payable till the total security deposit becomes 2.5% of the tendered amount. The security deposit shall be released after 5 years after date of completion.

7. PERFORMANCE GUARANTEE

7.1. The successful tenderer shall submit an irrevocable performance guarantee of 5% of the tendered amount in addition to other deposit mentioned elsewhere in the contract for his proper performance of the contract agreement within 15 days of issue of letter of acceptance of tender. This guarantee shall be in the form of Demand Draft/Pay order of irrevocable bank guarantee bond of any schedule bank or the State Bank of India in the specified perform a of Government Security, fixed deposit receipt pledged in favour of **Registrar, IIT Delhi** or as specified in the letter of acceptance of tender. The performance guarantee shall be initially valid up to the stipulated date of completion plus sixty days. This bank guarantee shall be kept valid till the recording of completion certificate for the work by the competent authority.

8. RATES

8.1. The work shall be treated as on works contract basis and the rates tendered shall be for complete items of work (except the materials, if any, stipulated for supply by the department) inclusive of all taxes, GST (including works contract tax, if any), duties, and levies etc. and all charges for items contingent to the work, such as, packing, forwarding, insurance, freight and delivery at site for the materials to the supplied by the contractor, watch and ward of all materials (including those, if any, supplied by the department), post installation services till defect liability period etc. for the work at site etc.

9. COMPLETENESS OF TENDER

9.1. All sundry equipments, fitting, unit assemblies, accessories, hardware items, foundation bolts, termination lugs for electrical connections and all other items which are useful and necessary for efficient assembly and installation of equipment and components of the work shall be deemed to have been included in the tender irrespective of the fact whether such items are specially mentioned in the tender documents or not.

10. STORAGE AND CUSTODY OF MATERIAL

10.1. The agency has to make his own arrangement for storage. No separate storage accommodation shall be provided by the department Watch and ward of the storage and their safe custody shall be responsibility till the final taking over of the installation by the department.

11. CARE OF THE BUILDING

11.1. Care shall be taken by the contractor while handling and installing the various equipment and components of the work to avoid damage to the building. He shall be responsible for repairing all damages and restoring the same to their original finish at his cost. He shall also remove at his cost all unwanted and waste material arising out of the installation from the site of work.

C ... Nil I Nil O Nil

Page 38 of 51

12. COMPLETION PERIOD

12.1. The completion period indicated in the tender documents is for the entire work of planning, designing, approval of drawings etc., arrangement of materials & equipments, delivery at site including transportation, installation, testing, commissioning and handing over of the entire system to the satisfaction of the Engineer-in-charge.

13. GUARANTEE

- 13.1. The contractor shall guarantee all AC installation as per specifications both for components and for system as a whole. All equipments shall be guaranteed for the date of commissioning against unsatisfactory performance and / or breakdown due to defective design, workmanship or material upto one year. The equipment or component, or any part thereof, so found defective during guarantee period shall be forthwith replaced free of cost to the satisfaction of the Engineer-in-Charge. In case it is felt by the department that undue delay is being caused by the contactor in doing this, the same will be got done by the department at the risk and cost of the contractor. Guarantee of compressors of the AC units shall be upto 5 (five) years after date of commissioning. The decision of Engineer-in-Charge in this regard shall be final & binding on the contractor.
- 13.2. The tenderer shall guarantee among other things, the following:
- 13.2.1. Quality, strength and performance of the material used as per manufacturer's standards.
- 13.2.2. Safe mechanical and electrical stress on all part under all specified conditions of operation.

14. POWER SUPPLY

14.1. Power supply shall be made available by the department at one point near the location of installation free of cost, if required. Further, the arrangement for tapping power supply from this point shall be made by the contractor.

15. EXTENT OF WORK

- 15.1. The work shall comprise of entire labour including supervision and all material necessary to make a complete installation and such tests and adjustment and commissioning as may be required by the department. The term complete installation shall not only mean major items of the plant and equipments covered by the specification but all incidental sundry components necessary for complete execution and satisfactory performance of installation with all layout charts whether or not those have been mentioned in details in the tender documents in connection with this contract as this is a turnkey job.
- 15.2. In addition to supply, installation, testing and commissioning of split/window type AC system including wall mounted indoor units, following works shall be deemed to be included with the scope of work to be executed by the tenderer-
- 15.2.1. Minor building works necessary for installation of equipments, foundation making of opening in walls or in floors and restoring them to their original condition / finish and necessary grouting etc. as required.

C ... Nil I Nil O Nil

Page 39 of 51

16. VALIDITY

16.1. Tenders shall be valid for acceptance for a period 90 days of days from the last date of submission of bid.

17. COMPLIANCE WITH REGULATIONS AND INDIAN STANDARDS

- **17.1.** All works shall be carried out in accordance with relevant regulation both statutory and those specified by the Indian Standards related to the works covered by this specification in particular, the equipment and installation will comply with the following:
- 17.1.1. Factories Act
- 17.1.2. Indian Electricity Rules
- **17.1.3.** B.I.S. & other standards as applicable
- 17.1.4. Workmen's compensation Act
- **17.1.5.** Statutory norms prescribed by local bodies like fire department, CEA, Power Supply Co. etc.

18. INDEMNITY

18.1. The successful tenderer shall at all times indemnify the department, consequent on this works contract. The successful tenderer shall be liable, in accordance with the Indian Law and Regulations for any accident occurring due to any cause and the contractor shall be responsible for any accident or damage incurred or claims arising there from during the period of erection, construction and putting into operation the equipments and ancillary equipment under the supervision of the successful tenderer in so far as the latter is responsible. The successful tenderer shall also provide all insurance including third party insurance as may be necessary to cover the risk. No extra payment would be made to the successful tenderer on account of the above.

19. ERECTION TOOLS

19.1. No tools and tackles either for unloading or for shifting the equipments for erection purposes would be made available by the department. The successful tender shall make his arrangement for all these facilities.

20. COOPERATION WITH OTHER AGENCIES AND OCCUPANTS OF THE BUILDING

20.1. The successful tenderer shall co-ordinate with other working contractors, if any and other occupants of different offices / Labs, etc., and exchange freely all technical information so as to make the execution of this work / contract smooth. No remuneration should be claimed from the department for such technical cooperation. If any unreasonable hindrance is caused to other agencies and any completed portion of the work has to be dismantled and re-done for want or cooperation and coordination by the tenderer during the course of work, such expenditure incurred will be recovered from the successful tenderer if the restoration work to the original condition or specification of the dismantled portion of work was not under taken by the tenderer himself.

C ... Nil I Nil O Nil

Page 40 of 51

21. MOBILIZATION ADVANCE

21.1. No mobilization advance shall be paid for this work.

22. INTERPRETING SPECIFICATION

- **22.1.** In interpreting the specification, the following order of decreasing importance shall be followed in case of contradictions:
- 22.1.1. Schedule of quantities
- 22.1.2. Technical Specification
- 22.1.3. Drawing (if any)
- 22.1.4. General Specification for Electrical Works of CPWD (relevant Parts)
- **22.1.5.** Relevant BIS or other international code in case BIS code is not available.

23. POLICY OF THE INSTITUTE

23.1. Institute has a policy against sexual harassment and is committed to providing an environment free from sexual harassment of women at the workplace. Contractor shall have to abide by the policy of the Institute with due diligence. Any violation on the part of the contractor shall be dealt with the extant rules of the Institute.

24. QUALITY OF MATERIALS

24.1. All materials and equipment supplied by the contractor shall be new. They shall be of such design, size and materials as to satisfactorily function under the rated conditions of operation and to withstand the environmental conditions at site. None of the material/ items/ equipment etc supplied shall be more than six months old from date of supply at site. Copy of GST Gate Pass/ Invoice/ Shipment / Custom Clearance certificate/ details (in case of imported equipment) shall be submitted to prove the date of manufacture & genuineness of the equipment/ machines supplied.

ANNEXURE - 1

<< Organization Letter Head >> DECLARATION

C ... Nil I Nil O Nil

Page 41 of 51

T.S./JE Plg

IIT Delhi

I / We, ______ hereby declare that all the information and data furnished by our organization with regard to this tender specification are true and complete to the best of our knowledge. I / we have gone through the specification, conditions and stipulations in details and agree to comply with the requirements and intent of specification.

detai	Is and agree to comply with the require	em	ents and intent of specification.
1	Name & Address of the bidder	:	
2	Phone	:	
3	E-mail	:	
4	Contact person name	:	
5	Mobile number	:	
6	GSTIN number	:	
7	PAN number	:	
8	UTR no. [if deposited online] for EMD	:	
9	DD / FDR No. & date [if uploaded	:	
	scanned copy] for EMD		
	BANK DETAILS of the Bidder		
10	Bank name	:	
11	Branch address	:	
12	Branch telephone no.	:	
13	MICR Code of the bank	:	
14	IFSC code	:	
15	Bank Account no.	:	
16	Type of account	:	
17	Pl attach one cancelled cheque	:	

We further declare that our organization has not been blacklisted / delisted or put to any holiday by any Institutional agency / Govt. Department / Public Sector Undertaking in the last three years.

(Signature& name of the bidder) Seal of the bidder

ANNEXURE - 2

TECHNICAL PARTICULARS

(To be filled and submitted by the bidder alongwith Technical Bid)

Details of AC Units the bidder is intended to supply: -

Page 42 of 51

C ... Nil I Nil O Nil

llT Delhi

1.01	Split AC: Cooling Capacity not less than 3500 Watt		Bidder's Comment
	Make	:	
	Model	:	
1.02	Split AC: Cooling Capacity not less than 5000 Watt		Bidder's Comment
	Make	:	
	Model	:	
1.03	Split AC: Cooling Capacity not less than 6000 Watt		Bidder's Comment
	Make	:	
	Model	:	N
		C	\mathcal{O}
2.01	Split AC H & C: Cooling Capacity not less than 6000 Watt		Bidder's Comment
	Make	:	
	Model	:	
3.01	Special Split AC: Cooling Capacity not less than 6000 Watt (30 m pipe)		Bidder's Comment
	Make	:	
	Model	:	
4.01	Window Type AC: Cooling Capacity not less than 3500 Watt		Bidder's Comment
	Make	:	
	Model	:	
4.02	Window Type AC: Cooling Capacity		Bidder's Comment
	not less than 5000 Watt		

C ... Nil I Nil O Nil

Page 43 of 51

AC Division		IIT Delhi
Make	:	
Model	:	

Sig. of the bidder / Contractor with stamp

C ... Nil I Nil O Nil

Page 44 of 51

T.S./JE Plg

BID SUBMISSION CHECK LIST

ONLINE BID SUBMISSION:

The bid (complete in all respect) must be uploaded online in two Envelops as explained below:-

	(Following do	Envelope – 1 cuments to be provided as single PDF file)	
SI. No.	Documents	Content	File Types
1		Annexure – 1 & 2	.PDF
2		EMD submission proof, Declaration	.PDF
3		Certificate of work experience as desired	.PDF
4		Certificate of GST Registration	.PDF
5		Affidavit as per provision on stamp paper	.PDF
6	Technical Bid	Acceptance to execute INTEGRITY PACT	.PDF
7		IITD 7 / 8 duly signed	.PDF
8		EPFO & ESIC Registration proof with updated challan	.PDF
9		Declaration of Local Content from OEM	.PDF
10		Valid Electrical Licence / Undertaking	.PDF
11		Any other document as specified in the NIT	.PDF
		Envelope – 2	
SI. No.	TYPES	Content	
1.	Financial Bid	Price bid should be submitted in BOQ format.	.EXL

SCHEDULE OF QUANTITY

C ... Nil I Nil O Nil

Page 45 of 51

T.S./JE Plg

llT Delhi

ltem No.	Description of items	Qty.	Rate	Unit	Amount
1	Supply, Installation, Testing and Commissioning of following capacity <u>high wall split type Air</u> <u>Conditioner unit for cooling</u> comprising factory built evaporator and condenser unit with remote controller with battery, as per following specifications: Star Rating: 5 Star; Compressor: Rotary type inverter inbuilt for variable speed operation; Refrigerant: Ecofriendly; Material of evaporator & Condenser : Copper; Suitable for operation on 230 volt, 50Hz, ac supply; warranty of machine: not less than 1 year; warranty of compressor: not less than 5 years. The work shall include making suitable opening in the wall / glass for drawing of refrigerant pipes, power connections to indoor and outdoor units, sealing the holes properly on the wall, mending good the damages, etc. including supplying and fixing of prototype adjustable readymade stand made of steel for resting condenser unit either on flat surface or on wall [as per site requirement - either floor mounted or wall mounted], having adequate strength for carrying load of condenser unit, duly prepainted with anticorrosive paint, nuts, bolts, fasteners, grouting / properly securing from accidental fall, fasteners, antivibration pad, etc. complete as required. (Note: cost of refrigerant pipes and power chord are not included, joint in pipeline and power chord are not included, joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi / O General / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]				
1.01 1.02	Rated cooling capacity: Not less than 3500 watt Rated cooling capacity: Not less than 5000 watt	15		Each	
1.02	Rated cooling capacity: Not less than 5000 watt Rated cooling capacity: Not less than 6000 watt	32		Each	
1.05	hated cooming capacity. Not less than 0000 watt	12	l	Each	

 2 Supply, Installation, Testing and Commissioning of following capacity high wall split type Air Conditioner unit for heating & cooling (H&C) comprising factory built evaporator and condenser unit with remote controller with battery, as per following specifications: Star Rating: not less than 3 Star; Compressor: Rotary type inverter inbuilt for variable speed operation, Refrigerant: Ecofriendly; Material of evaporator & Condenser : Copper; Suitable for operation on 230 volt, 50Hz, ac supply; warranty of machine: not less than 1 year; warranty of compressor: not less than 1 year; warranty of compressor: not less than 1 year; warranty of machine: not less than 1 year; warranty of compressor: not less than 1 year; warranty of steel for resting condenser unit, sealing the holes properly on the wall, mending good the damages, etc. including supplying and fixing of prototype adjustable readymade stand made of steel for resting condenser unit, duly prepainted with anticorrosive paint, nuts, bolts, fasteners, grouting / properly securing from accidental fall, fasteners, antivibration mounting, etc. complete as required. (Note: cost of refrigerant pipes and power chord are not included, joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi / O General / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG] 2.01 Rated cooling capacity: Not less than 6000 watt 1 				 	
2.01 Rated cooling capacity: Not less than 6000 watt 1 Each		following capacity high wall split type Air Conditioner unit for heating & cooling (H&C) comprising factory built evaporator and condenser unit with remote controller with battery, as per following specifications: Star Rating: not less than 3 Star; Compressor: Rotary type inverter inbuilt for variable speed operation; Refrigerant: Ecofriendly; Material of evaporator & Condenser : Copper; Suitable for operation on 230 volt, 50Hz, ac supply; warranty of machine: not less than 1 year; warranty of compressor: not less than 5 years. The work shall include making suitable opening in the wall / glass for drawing of refrigerant pipes, power connections to indoor and outdoor units, sealing the holes properly on the wall, mending good the damages, etc. including supplying and fixing of prototype adjustable readymade stand made of steel for resting condenser unit either on flat surface or on wall [as per site requirement - either floor mounted or wall mounted], having adequate strength for carrying load of condenser unit, duly prepainted with anticorrosive paint, nuts, bolts, fasteners, grouting / properly securing from accidental fall, fasteners, antivibration mounting, etc. complete as required. (Note: cost of refrigerant pipes and power chord are not included, joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi / O General / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]			
	2.01	Rated cooling capacity: Not less than 6000 watt	1	Each	

C ... Nil I Nil O Nil

Page 47 of 51

 3 Supply, Installation, Testing and Commissioning of following capacity special type high wall split type Air Conditioner unit for Cooling (that can sustain longer refrigerant pipeline upto 30 metre without deration) comprising factory built evaporator and condenser unit with remote controller with battery, as per following specifications: Star Rating: 5 Star; Compressor: Advanced Hyper Tropical twin Rotary type inverter or equivalent inbuilt for variable speed operation; Refrigerant: Ecofriendly; Material of evaporator & Condenser : Copper; Suitable for operation on 230 volt, 50Hz, ac supply; warranty of machine: not less than 1 year; The work shall include making suitable opening / core cutting in the wall / glass / shaft for drawing of refrigerant pipes, power connections to indoor and outdoor units, sealing the holes properly on the wall, mending good the damages, etc. including supplying and fixing of prototype adjustable readymade stand made of steel for resting condenser unit either on flat surface or on wall [as per site requirement], having adequate strength for carrying load of condenser unit, duly prepainted with anticorrosive paint, nuts, bolts, fasteners, grouting / properly securing from accidental fall, fasteners, antivibration pad, etc. complete as required. (Note: cost of refrigerant pipes and power chord are not included, the machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipes and power chord are not included, the machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipes. Mode24CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG] 3.01 Rated cooling capacity: Not less than 6000 watt 1 Each 			•			
Air Conditioner unit for cooling (that can sustain longer refrigerant pipeline upto 30 metre without deration) comprising factory built evaporator and condenser unit with remote controller with battery, as per following specifications: Star Rating: 5 Star; Compressor: Advanced Hyper Tropical twin Rotary type inverter or equivalent inbuilt for variable speed operation, Refrigerant: Ecofriendly; Material of evaporator & Condenser : Copper; Suitable for operation on 230 volt, 50Hz, ac supply; warranty of machine: not less than 1 year; The work shall include making suitable opening / core cutting in the wall / glass / shaft for drawing of refrigerant pipes, power connections to indoor and outdoor units, sealing the holes properly on the wall, mending good the damages, etc. including supplying and fixing of prototype adjustable readymade stand made of steel for resting condenser unit either on flat surface or on wall [as per site requirement], having adequate strength for carrying load of condenser unit, duly prepainted with anticorrosive paint, nuts, bolts, fasteners, grouting / properly securing from accidental fall, fasteners, antivibration pad, etc. complete as required. (Note: cost of refrigerant pipes and power chord are not included, the machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipeline of 30 metre. joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASGG24CGTB-B / AOGG24CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]	3					
longer refrigerant pipeline upto 30 metre without deration) comprising factory built evaporator and condenser unit with remote controller with battery, as per following specifications: Star Rating: 5 Star; Compressor: Advanced Hyper Tropical twin Rotary type inverter or equivalent inbuilt for variable speed operation; Refrigerant: Ecofriendly; Material of evaporator & Condenser : Copper; Suitable for operation on 230 volt, 50Hz, ac supply; warranty of machine: not less than 1 year; The work shall include making suitable opening / core cutting in the wall / glass / shaft for drawing of refrigerant pipes, power connections to indoor and outdoor units, sealing the holes properly on the wall, mending good the damages, etc. including supplying and fixing of prototype adjustable readymade stand made of steel for resting condenser unit either on flat surface or on wall [as per site requirement], having adequate strength for carrying load of condenser unit, duly prepainted with anticorrosive paint, nuts, bolts, fasteners, grouting / properly securing from accidental fall, fasteners, antivibration pad, etc. complete as required. (Note: cost of refrigerant pipes and power chord are not included, the machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipes and power chord are not included, the machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipes [A DOMERE. joint in pipeline and power chord is prohibited] [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASGG24CGTB-B / AOGG24CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]		following capacity special type high wall split type				
deration) comprising factory built evaporator and condenser unit with remote controller with battery, as per following specifications: Star Rating: 5 Star; Compressor: Advanced Hyper Tropical twin Rotary type inverter or equivalent inbuilt for variable speed operation; Refrigerant: Ecofriendly; Material of evaporator & Condenser : Copper; Suitable for operation on 230 volt, 50Hz, ac supply; warranty of machine: not less than 1 year; The work shall include making suitable opening / core cutting in the wall / glass / shaft for drawing of refrigerant pipes, power connections to indoor and outdoor units, sealing the holes properly on the wall, mending good the damages, etc. including supplying and fixing of prototype adjustable readymade stand made of steel for resting condenser unit either on flat surface or on wall [as per site requirement], having adequate strength for carrying load of condenser unit, duly prepainted with anticorrosive paint, nuts, bolts, fasteners, grouting / properly securing from accidental fall, fasteners, antivibration pad, etc. complete as required. (Note: cost of refrigerant pipes and power chord are not included, the machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipeline of 30 metre, joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASG624CGTB-B / AOG624CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]		Air Conditioner unit for cooling (that can sustain				
condenser unit with remote controller with battery, as per following specifications: Star Rating: 5 Star; Compressor: Advanced Hyper Tropical twin Rotary type inverter or equivalent inbuilt for variable speed operation; Refrigerant: Ecofriendly; Material of evaporator & Condenser : Copper; Suitable for operation on 230 volt, 50Hz, ac supply; warranty of machine: not less than 1 year; The work shall include making suitable opening / core cutting in the wall / glass / shaft for drawing of refrigerant pipes, power connections to indoor and outdoor units, sealing the holes properly on the wall, mending good the damages, etc. including supplying and fixing of prototype adjustable readymade stand made of steel for resting condenser unit either on flat surface or on wall [as per site requirement], having adequate strength for carrying load of condenser unit, duly prepainted with anticorrosive paint, nuts, bolts, fasteners, grouting / properly securing from accidental fall, fasteners, antivibration pad, etc. complete as required. (Note: cost of refrigerant pipes and power chord are not included, the machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipeline of 30 metre. joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASG624CGTB-B / AOG624CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]		longer refrigerant pipeline upto 30 metre without				
as per following specifications: Star Rating: 5 Star; Compressor: Advanced Hyper Tropical twin Rotary type inverter or equivalent inbuilt for variable speed operation; Refrigerant: Ecofriendly; Material of evaporator & Condenser : Copper; Suitable for operation on 230 volt, 50Hz, ac supply; warranty of machine: not less than 1 year; The work shall include making suitable opening / core cutting in the wall / glass / shaft for drawing of refrigerant pipes, power connections to indoor and outdoor units, sealing the holes properly on the wall, mending good the damages, etc. including supplying and fixing of prototype adjustable readymade stand made of steel for resting condenser unit either on flat surface or on wall [as per site requirement], having adequate strength for carrying load of condenser unit, duly prepainted with anticorrosive paint, nuts, bolts, fasteners, grouting / properly securing from accidental fall, fasteners, antivibration pad, etc. complete as required. (Note: cost of refrigerant pipes and power chord are not included, the machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipeline of 30 metre, joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASG24/CGTB-B / AloG24/CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]		deration) comprising factory built evaporator and				
Star Rating: 5 Star; Compressor: Advanced Hyper Tropical twin Rotary type inverter or equivalent inbuilt for variable speed operation; Refrigerant: Ecofriendly; Material of evaporator & Condenser : Copper; Suitable for operation on 230 volt, 50Hz, ac supply; warranty of machine: not less than 1 year; The work shall include making suitable opening / core cutting in the wall / glass / shaft for drawing of refrigerant pipes, power connections to indoor and outdoor units, sealing the holes properly on the wall, mending good the damages, etc. including supplying and fixing of prototype adjustable readymade stand made of steel for resting condenser unit either on flat surface or on wall [as per site requirement], having adequate strength for carrying load of condenser unit, duly prepainted with anticorrosive paint, nuts, bolts, fasteners, grouting / properly securing from accidental fall, fasteners, antivibration pad, etc. complete as required. (Note: cost of refrigerant pipes and power chord are not included, the machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipeline of 30 metre, joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASGC24/CGTB-B / AOGG24/CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]		condenser unit with remote controller with battery,				
Tropical twin Rotary type inverter or equivalent inbuilt for variable speed operation; Refrigerant: Ecofriendly; Material of evaporator & Condenser : Copper; Suitable for operation on 230 volt, 50Hz, ac supply; warranty of machine: not less than 1 year; The work shall include making suitable opening / core cutting in the wall / glass / shaft for drawing of refrigerant pipes, power connections to indoor and outdoor units, sealing the holes properly on the wall, mending good the damages, etc. including supplying and fixing of prototype adjustable readymade stand made of steel for resting condenser unit either on flat surface or on wall [as per site requirement], having adequate strength for carrying load of condenser unit, duly prepainted with anticorrosive paint, nuts, bolts, fasteners, grouting / properly securing from accidental fall, fasteners, antivibration pad, etc. complete as required. (Note: cost of refrigerant pipes and power chord are not included, the machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipeline of 30 metre, joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASG624CGTB-B / AOGG24CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]		as per following specifications:				
inbuilt for variable speed operation; Refrigerant: Ecofriendly; Material of evaporator & Condenser : Copper; Suitable for operation on 230 volt, 50Hz, ac supply; warranty of machine: not less than 1 year; The work shall include making suitable opening / core cutting in the wall / glass / shaft for drawing of refrigerant pipes, power connections to indoor and outdoor units, sealing the holes properly on the wall, mending good the damages, etc. including supplying and fixing of prototype adjustable readymade stand made of steel for resting condenser unit either on flat surface or on wall [as per site requirement], having adequate strength for carrying load of condenser unit, duly prepainted with anticorrosive paint, nuts, bolts, fasteners, grouting / properly securing from accidental fall, fasteners, antivibration pad, etc. complete as required. (Note: cost of refrigerant pipes and power chord are not included, the machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipeline of 30 metre. joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASGC24CGTB-B / AOGG24CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]		Star Rating: 5 Star; Compressor: Advanced Hyper				
Ecofriendly; Material of evaporator & Condenser : Copper; Suitable for operation on 230 volt, 50Hz, ac supply; warranty of machine: not less than 1 year; The work shall include making suitable opening / core cutting in the wall / glass / shaft for drawing of refrigerant pipes, power connections to indoor and outdoor units, sealing the holes properly on the wall, mending good the damages, etc. including supplying and fixing of prototype adjustable readymade stand made of steel for resting condenser unit either on flat surface or on wall [as per site requirement], having adequate strength for carrying load of condenser unit, duly prepainted with anticorrosive paint, nuts, bolts, fasteners, grouting / properly securing from accidental fall, fasteners, antivibration pad, etc. complete as required. (Note: cost of refrigerant pipes and power chord are not included, the machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipeline of 30 metre, joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASG624CGTB-B / AOG624CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]		Tropical twin Rotary type inverter or equivalent				
Copper; Šuitable for operation on 230 volt, 50Hz, ac supply; warranty of machine: not less than 1 year; The work shall include making suitable opening / core cutting in the wall / glass / shaft for drawing of refrigerant pipes, power connections to indoor and outdoor units, sealing the holes properly on the wall, mending good the damages, etc. including supplying and fixing of prototype adjustable readymade stand made of steel for resting condenser unit either on flat surface or on wall [as per site requirement], having adequate strength for carrying load of condenser unit, duly prepainted with anticorrosive paint, nuts, bolts, fasteners, grouting / properly securing from accidental fall, fasteners, antivibration pad, etc. complete as required. (Note: cost of refrigerant pipes and power chord are not included, the machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipeline of 30 metre, joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASGG24CGTB-B / AOGG24CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]		inbuilt for variable speed operation; Refrigerant:				
ac supply; warranty of machine: not less than 1 year; The work shall include making suitable opening / core cutting in the wall / glass / shaft for drawing of refrigerant pipes, power connections to indoor and outdoor units, sealing the holes properly on the wall, mending good the damages, etc. including supplying and fixing of prototype adjustable readymade stand made of steel for resting condenser unit either on flat surface or on wall [as per site requirement], having adequate strength for carrying load of condenser unit, duly prepainted with anticorrosive paint, nuts, bolts, fasteners, grouting / properly securing from accidental fall, fasteners, antivibration pad, etc. complete as required. (Note: cost of refrigerant pipes and power chord are not included, the machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipeline of 30 metre , joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASGG24CGTB-B / AOGG24CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]		Ecofriendly; Material of evaporator & Condenser :				
year; The work shall include making suitable opening / core cutting in the wall / glass / shaft for drawing of refrigerant pipes, power connections to indoor and outdoor units, sealing the holes properly on the wall, mending good the damages, etc. including supplying and fixing of prototype adjustable readymade stand made of steel for resting condenser unit either on flat surface or on wall [as per site requirement], having adequate strength for carrying load of condenser unit, duly prepainted with anticorrosive paint, nuts, bolts, fasteners, grouting / properly securing from accidental fall, fasteners, antivibration pad, etc. complete as required. (Note: cost of refrigerant pipes and power chord are not included, the machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipeline of 30 metre, joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASGG24CGTB-B / AOGG24CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]		Copper; Suitable for operation on 230 volt, 50Hz,				
opening / core cutting in the wall / glass / shaft for drawing of refrigerant pipes, power connections to indoor and outdoor units, sealing the holes properly on the wall, mending good the damages, etc. including supplying and fixing of prototype adjustable readymade stand made of steel for resting condenser unit either on flat surface or on wall [as per site requirement], having adequate strength for carrying load of condenser unit, duly prepainted with anticorrosive paint, nuts, bolts, fasteners, grouting / properly securing from accidental fall, fasteners, antivibration pad, etc. complete as required. (Note: cost of refrigerant pipes and power chord are not included, the machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipeline of 30 metre, joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASGG24CGTB-B / AOGG24CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]		ac supply; warranty of machine: not less than 1				
drawing of refrigerant pipes, power connections to indoor and outdoor units, sealing the holes properly on the wall, mending good the damages, etc. including supplying and fixing of prototype adjustable readymade stand made of steel for resting condenser unit either on flat surface or on wall [as per site requirement], having adequate strength for carrying load of condenser unit, duly prepainted with anticorrosive paint, nuts, bolts, fasteners, grouting / properly securing from accidental fall, fasteners, antivibration pad, etc. complete as required. (Note: cost of refrigerant pipes and power chord are not included, the machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipeline of 30 metre, joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASGG24CGTB-B / AOGG24CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]		year; The work shall include making suitable				
indoor and outdoor units, sealing the holes properly on the wall, mending good the damages, etc. including supplying and fixing of prototype adjustable readymade stand made of steel for resting condenser unit either on flat surface or on wall [as per site requirement], having adequate strength for carrying load of condenser unit, duly prepainted with anticorrosive paint, nuts, bolts, fasteners, grouting / properly securing from accidental fall, fasteners, antivibration pad, etc. complete as required. (Note: cost of refrigerant pipes and power chord are not included, the machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipeline of 30 metre, joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASGG24CGTB-B / AOGG24CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]		opening / core cutting in the wall / glass / shaft for				
properly on the wall, mending good the damages, etc. including supplying and fixing of prototype adjustable readymade stand made of steel for resting condenser unit either on flat surface or on wall [as per site requirement], having adequate strength for carrying load of condenser unit, duly prepainted with anticorrosive paint, nuts, bolts, fasteners, grouting / properly securing from accidental fall, fasteners, antivibration pad, etc. complete as required. (Note: cost of refrigerant pipes and power chord are not included, the machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipeline of 30 metre , joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASGG24CGTB-B / AOGG24CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]		drawing of refrigerant pipes, power connections to				
etc. including supplying and fixing of prototype adjustable readymade stand made of steel for resting condenser unit either on flat surface or on wall [as per site requirement], having adequate strength for carrying load of condenser unit, duly prepainted with anticorrosive paint, nuts, bolts, fasteners, grouting / properly securing from accidental fall, fasteners, antivibration pad, etc. complete as required. (Note: cost of refrigerant pipes and power chord are not included, the machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipeline of 30 metre , joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASGG24CGTB-B / AOGG24CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]		indoor and outdoor units, sealing the holes				
adjustable readymade stand made of steel for resting condenser unit either on flat surface or on wall [as per site requirement], having adequate strength for carrying load of condenser unit, duly prepainted with anticorrosive paint, nuts, bolts, fasteners, grouting / properly securing from accidental fall, fasteners, antivibration pad, etc. complete as required. (Note: cost of refrigerant pipes and power chord are not included, the machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipeline of 30 metre, joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASGG24CGTB-B / AOGG24CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]		properly on the wall, mending good the damages,				
resting condenser unit either on flat surface or on wall [as per site requirement], having adequate strength for carrying load of condenser unit, duly prepainted with anticorrosive paint, nuts, bolts, fasteners, grouting / properly securing from accidental fall, fasteners, antivibration pad, etc. complete as required. (Note: cost of refrigerant pipes and power chord are not included, the machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipeline of 30 metre , joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASGG24CGTB-B / AOGG24CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]		etc. including supplying and fixing of prototype				
wall [as per site requirement], having adequate strength for carrying load of condenser unit, duly prepainted with anticorrosive paint, nuts, bolts, fasteners, grouting / properly securing from accidental fall, fasteners, antivibration pad, etc. complete as required. (Note: cost of refrigerant pipes and power chord are not included, the machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipeline of 30 metre, joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASGG24CGTB-B / AOGG24CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]		adjustable readymade stand made of steel for				
strength for carrying load of condenser unit, duly prepainted with anticorrosive paint, nuts, bolts, fasteners, grouting / properly securing from accidental fall, fasteners, antivibration pad, etc. complete as required. (Note: cost of refrigerant pipes and power chord are not included, the machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipeline of 30 metre , joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASGG24CGTB-B / AOGG24CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]		resting condenser unit either on flat surface or on				
prepainted with anticorrosive paint, nuts, bolts, fasteners, grouting / properly securing from accidental fall, fasteners, antivibration pad, etc. complete as required. (Note: cost of refrigerant pipes and power chord are not included, the machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipeline of 30 metre, joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASGG24CGTB-B / AOGG24CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]		wall [as per site requirement], having adequate				
fasteners, grouting / properly securing from accidental fall, fasteners, antivibration pad, etc. complete as required. (Note: cost of refrigerant pipes and power chord are not included, the machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipeline of 30 metre, joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASGG24CGTB-B / AOGG24CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]		strength for carrying load of condenser unit, duly				
accidental fall, fasteners, antivibration pad, etc. complete as required. (Note: cost of refrigerant pipes and power chord are not included, the machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipeline of 30 metre, joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASGG24CGTB-B / AOGG24CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]		prepainted with anticorrosive paint, nuts, bolts,				
complete as required. (Note: cost of refrigerant pipes and power chord are not included, the machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipeline of 30 metre , joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASGG24CGTB-B / AOGG24CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]		fasteners, grouting / properly securing from				
pipes and power chord are not included, the machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipeline of 30 metre, joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASGG24CGTB-B / AOGG24CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]		accidental fall, fasteners, antivibration pad, etc.				
machine should run at 55 deg C ambient without tripping and suitable for long refrigerant pipeline of 30 metre, joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASGG24CGTB-B / AOGG24CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]		complete as required. (Note: cost of refrigerant				
tripping and suitable for long refrigerant pipeline of 30 metre, joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASGG24CGTB-B / AOGG24CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]						
pipeline of 30 metre, joint in pipeline and power chord is prohibited) [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASGG24CGTB-B / AOGG24CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]		5				
chord is prohibited) [Acceptable make of AC: Mitsubishi Heavy Duty / O General reference Model ASGG24CGTB-B / AOGG24CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]						
Mitsubishi Heavy Duty / O General reference Model ASGG24CGTB-B / AOGG24CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]						
ASGG24CGTB-B / ÁOGG24CGTB-B / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]						
Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]						
Daikin / LG]						
		,				
3.01 Rated cooling capacity: Not less than 6000 watt 1 Each						
	3.01	Rated cooling capacity: Not less than 6000 watt	1		Each	

C ... Nil I Nil O Nil

Page 48 of 51

T.S./JE Plg

llT Delhi

4	Supply, Installation, Testing and Commissioning of following capacity <u>Window type Air Conditioner</u> unit comprising factory built evaporator and condenser unit with remote controller with battery, in the existing window, properly sealing the gap of window with insulation, complete with electrical connections etc. anti vibration pad as required for installation as per following specification: Star Rating: 5 Star; Compressor: Rotary type; Refrigerant: Ecofriendly; Material of evaporator & Condenser : Copper; Suitable for operation on 230 volt, 50Hz, ac supply; warranty of machine: not less than 1 year; warranty of compressor: not less than 5 years [Acceptable make of AC: Mitsubishi / O General / Hitachi / Panasonic / Blue Star / Carrier / Voltas / Lloyd / Daikin / LG]			
4.01	Rated cooling capacity: Not less than 3500 watt	3	Each	
4.02	Rated cooling capacity: Not less than 5000 watt	6	Each	
5	Supply, Installation, testing and commissioning including vaccumiazation and Nitrogen testing of following nominal sizes of soft drawn copper refrigerant piping for Split AC system, complete with fittings, with suitable adjustable ring type hanger supports (wherever required), jointing / brazing including accessories, cutting of glass window wherever required with proper finishing, insulated with XPLE Class-O tubular insulation / with Class-O closed cell elastometric nitrile rubber tubular sleeves sections of specified thickness as given below for Suction and Liquid lines, all accessories as per specifications etc. packing of all leakage either on wall or window with silicon / insulation, as required : [Acceptable make of copper pipes : Uniflow / Manibhadra / Ganpati / Mexflow / Mandev / Indigo / Godrej / Visiaro) Acceptable make of tubular insulation: Visiaro / Marshland / Avi Global / Armaflex / Aajjo / Dynamic / Uttam] NOTE: (1) The copper piping and piping circuit			
5.01	6.4 mm (1/4") dia (OD) (Soft drawn) with tube thickness 1.2 mm with 9 mm thick insulation			
		500	Metre	

C ... Nil I Nil O Nil

T.S./JE Plg

5.02	9.5 mm (3/8") dia (OD) (Soft drawn) with tube thickness 1.2 mm with 9 mm thick insulation	300	Metre
5.03	12.7 mm (1/2") dia (OD) (Soft drawn) with tube thickness 1.2 mm with 9 mm thick insulation	400	Metre
5.04	15.86 mm (5/8") dia (OD) (Soft drawn) with tube thickness 1.2 mm with 9 mm thick insulation	400	Metre
6	<u>GI TRAY SUPPORT:</u> Supplying and installing following size of perforated Hot Dipped Galvanised Iron Cable tray (galvanisation thickness not less than 50 microns) with perforation not more than 17.5% in convenient sections, joined with connectors, suspended / supported from the ceiling / wall with GI suspenders including GI bolts and nuts, GI C-Channels, etc. including GI protective sheet covering outside the room as required. (Only for outdoor portion)		
6.01	150 mm width x 50 mm depth x 1.6 mm thickness	100	Metre
7	DRAIN PIPE: Supplying and laying of ISI marked CPVC pipe of 32 mm dia for draining of sweated water from AC evaporator (indoor) unit including providing tee, joints, elbows, supports, etc. insulated with XLPE class - O tubular insulation / worth Class-O closed cell elastomeric nitrile rubber tubular sleeves sections of 19 mm thick etc. complete as required.	200	Metre
8	DRAIN PIPE: Supplying and laying of ISI marked flexible braided PVC pipe of 25 mm dia for draining of sweated water from AC evaporator (indoor) unit including providing tee, joints, elbows, supports, etc. wherever required etc. complete as required.	250	Metre
9	Supplying and fixing DP sheet steel enclosure on surface / recess alongwith 10 / 16 A, 240 V "C" curve DP MCB complete with connections, testing and commissioning etc. as required.	30	Each
		50	Laci

Page 50 of 51

C Divisio	n		IIT C	elhi
10	Supplying and laying of ISI marked FRLS industrial multistranded following type copper cable of following size of 1.1 kv grade conforming to IS694:2010 including making connection etc. for power supply between indoor and outdoor unit and drawing power from nearest DB, etc. on surface / recess complete as required. (Acceptable make: KEI / Finolex / Polycab / Universal / Havells / Gloster / RR Kabel / Rallison) [NB: Single stranded cable not to be used]			
10.01	4 core x 2.5 sqmm unarmoured	900	Metre	
11	Supplying and charging of refrigerant (R-32 / R407 / R410 / any environment friendly) as applicable for AC unit for topping up where pipe lines are lengthy etc. as directed.	20	Kg	
12	Supplying and fixing of 10 mm thick wooden board of suitable size for fixing of indoor unit of split AC on aluminium channel including making holes, providing screws etc. as required.	75	sqft	
13	Supplying and fixing of FR PVC trunking system and accessories for covering / accommodating AC pipes, drain pipe and power chord (size not less than 100 mm x 100 mm)for aesthetics in specific areas complete as directed.	200	Metre	
14	Supplying and fixing 5 amps to 32 amps rating, 240/415 volts, "C" curve, miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections, testing and commissioning etc. as required.			
14.01	Single pole	30	Each	
	Total			***

T.S. Plg.

AEE-in-charge AC Division

C ... Nil I Nil O Nil

Page 51 of 51

T.S./JE Plg