



INDIAN INSTITUTE OF TECHNOLOGY DELHI
Hauz Khas, New Delhi – 110016

Office of Executive Engineer (Electrical)

Corrigendum

Dept.: ELECTRI.-(I)

- 6 OCT 2015

Ref. No.: 20.../S.../WME.../28...

Sr. No.	NIT No.	Name of work & Location	Estimated cost put to Bid	Earnest Money	Period of completion	Date of pre-bid meeting	Last date & time of uploading of EMD e-Tender processing fee and other documents as specified in the press notice	Time & date of opening of Technical & Commercial Bid	Time & date of opening of financial bids	e-Tender processing fee
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	8645/44/EE(E)/IITDELHI/2015-16	NAME OF WORK :- Replacement of existing 2 x 100 TR. Reciprocating Chillers with 02 x 100 TR. Water cooled energy efficient screw chillers of Central Air-Conditioning Plant at Computer Service Center in IIT Delhi.	Rs 1,17,36,546/-	Rs 2,34,750/-	04 Month	30/09/2015 at 11.00 AM.	07/10/2015 up to 02.30 pm.	12/10/2015, at 02:30 pm.	To be announced later	Rs. 8,550/-

Due to technical reasons the Last date & time of uploading of EMD , e-Tender processing fee and other documents as specified in the press notice, Time & date of opening of Technical & Commercial Bid and Time & date of opening of financial bids. Extended as per following.

Last date & time of uploading of EMD , e-Tender processing fee and other documents as specified in the press notice.....14.10.2015 up to 2:30PM

Time & date of opening of Technical & Commercial Bid.....15.10.2015 at 3:00PM

Time & date of opening of financial bids..... To be announced later.

Others terms & conditions are same as per the NIT -8645/ 44/EE(E) /IITDELHI/2015-16

Executive Engineer (E),
For & on Behalf of BOG, IIT Delhi



INDIAN INSTITUTE OF TECHNOLOGY: DELHI.
HAUZ KHAS, NEW DELHI-110016

Dept.: ELECTRI.-(I)

- 6 OCT 2015

Ref. No.: 20. /S/IVME 380

OFFICE OF THE EXECUTIVE ENGINEER (E)

SUBJECT :- Minutes of Pre-bid meeting held on 30/09/2015 in the office of I.E

NAME OF WORK :- Replacement of existing 2 x 100 TR. Reciprocating Chillers with 02 x 100 TR. Water cooled energy efficient screw chillers of Central Air-Conditioning Plant at Computer Service Center in IIT Delhi.

NIT No :- 8645/ 44/EE(E) /IITDELHI/2015-16

Amount Rs. 1,17,36,545/-

Earnest Money :-Rs. 2,34,731/-

Following were present :-

Representative of IIT Delhi

1. I.E.
2. EE(Electrical)
3. AE(Electrical)/AC
4. D.A.(Works)

Representative of Bidders

1. Mr. Vivek Sainy (Representative of M/s HVAC)
2. Mr. Sobhit Bisaria (Representative of M/s Blue Star)
3. Mr. Raghunath Padhi (Representative of M/s Airways Engineers Pvt.Ltd)

Sr. /Item No.	Item Description		Remarks
	Given AS	Read as as per discussed in the pre Bid meeting	
1	<p>SI Item no.1 of BOQ (Chilling Machine)</p> <p>As per sr.nopage58 of tender document the compressor semi hermetic screw have been asked for whereas vide SI page 47 of tender document chilling machine with mono screw hermetic type accepted .Please clarify the type of chilling machine have been asked.</p>	<p>Mono Screw/ Hermetic type not acceptable</p>	<p>Mail received from M/s AIRTEMP Engineers</p>
2	<p>SI Item no.3 of BOQ (Chilled Water Pump)</p> <p>The Chilled water pump flow rates appears to be on higher side and in our opinion it should be 244 USGPM as mentioned in SI Item no. 3 of BOQ against Chilling machine</p>	<p>3. The Chilled water pump flow rates should be 244 USGPM in SI Item no. 3 of BOQ</p>	<p>Mail received from M/s AIRTEMP Engineers</p>

3	<p>Sl Item no.21 of BOQ (Dismantling) The quantity mentioned against this Item is 5 Lots .Appears to be typographical mistake this may please be clarified accordingly.</p>	<p>The Five Lots are as Follows :- Lot No.1 All Electrical Panels with Cables Lot No.2 All AHU's Complete Lot No.3 All Condensers , Chillers Pipe lines and Valves Lot No.4 All Condensers , Chillers Pumps and other accessories Lot No.5 compressor, Condenser, Chillers with all Foundations and Melba with any other dismantled Material.</p>	<p>Mail received from M/s AIRTEMP Engineers</p>
4	<p>As per CPWD Manual the security amount is @ 2.5% of Tender amount but in the tender documents Security deposit @5% have mentioned (please refer Sl. Page 23 of Tender documents)</p>	<p>No Change in the NIT Condition is acceptable</p>	<p>Mail received from M/s AIRTEMP Engineers</p>
5.	<p>Sl Item no.5 of BOQ (Chilling Machine) Floor mounted Chilled water Double skin type Air handling Units shall be made of 25 mm thick panel consisting of 0.6 mm (inner skin) plane G.I. sheet and 0.6 mm (outer skin) pre painted G.I. sheet with polyurethane foam (PUF) insulation of (density 38+2 kg/Cu mtrs)</p>	<p>Floor mounted Chilled water Double skin type Air handling Units shall be made of 25 (+-2) mm thick panel consisting of 0.6 mm (inner skin) plane G.I. sheet and 0.6 mm (outer skin) pre painted G.I. sheet with polyurethane foam (PUF) insulation of (density 38+2 kg/Cu mtrs)</p>	<p>Mr. Vivek Sainy Mr. Sobhit Bisaria</p>

Last date & time of uploading of EMD, e-Tender processing fee and other documents as specified in the press notice.....14/10/2015 up to 2:30PM

Time & date of opening of Technical & Commercial Bid.....15/10/2015 at 3:00PM

Time & date of opening of financial bids.....To be announced Later


EXECUTIVE ENGINEER (E)